



Transmission Development Plan (TDP 2013 – 2022)

Public Presentation
23 October 2012

The Objective of the presentation is to:

- Address feedback from the previous engagements (DPE / NERSA / Public Forum)
- Contextualise the planning timelines relating to the demand forecast and generation patterns
- Share assumptions and results from the Transmission Development Plan 2013 – 2022
- Share information on the process for the Transmission Refurbishment and Capital Spares Plan
- Share information on the estimated Transmission Capital Investment Requirements for the period 2013 – 2022
- To solicit comments and inputs from stakeholders on the Transmission Plans

Main topics relate to:

- Integration of TDP with Key stakeholders (eg. Distribution, Munics, other Government Departments etc.)
- Distribution Master / Development Plans
- Transmission Refurbishment Plans
- Integration of Renewable Energy (Wind / Solar), distributed generation and IPPs in general
- Synchronisation of planning timelines to cater for the IRP
- Achieving Grid Code compliance

Since April 2012 Transmission has been involved in joint discussions with Eskom Distribution and local Metros with the main purpose of the engagements “to seek alignment of the TDP with the Provinces’ security-of-supply aspirations”

The following meetings have already taken place:

Gauteng:	13 April 2012
Mpumalanga:	28 June 2012
Northern Cape:	10 July 2012
Northwest:	20 July 2012
Western Cape:	6 August 2012
Eastern Cape:	8 August 2012
KZN:	13 August 2012

Some of the concerns raised at the above meetings include:

- A need was expressed to pursue N-2 in Gauteng, due to the non-availability of servitudes and the concentration of load in a small geographical area.
- A need was expressed to integrate distribution and transmission plans and investigate the migration from 66kV to 132kV in the North-West Province.
- Some alignment gaps were identified between transmission plans and distribution plans
- Servitude challenges across all provinces

- **Engagements with RE stakeholders (Wind, Solar)**
- **Involvement in the Presidential Infrastructure Coordinating Commission (PICC) / Strategic Integrated Projects (SIP) Program**

A decorative graphic on the left side of the slide. It consists of two overlapping circular frames. The upper frame shows a white wind turbine against a clear blue sky. The lower frame shows a sunset or sunrise over a landscape with mountains. The frames are surrounded by several thin, concentric, hand-drawn style lines in a light brown or tan color. A large, curved, light blue shape is visible in the top-left corner of the slide, and a thin, curved line extends from the bottom-left corner towards the center.

Planning for the South African Integrated Power System

Integrated Resource Plan

- The Department of Energy (Energy Planner) is accountable for the Country Electricity Plan, which is called the Integrated Resource Plan for Electricity (IRP 2010-2030).
- The Integrated Resource Plan (IRP) is intended to drive all new generation capacity development.
- NERSA licences new generators according to this determination.


Strategic Grid Plan


- The Strategic Grid Plan formulates long term strategic transmission corridor requirements
- The Plan is based on a range of generation scenarios, and associated strategic network analysis
- Horizon date is 20 years
- Updated every 2 - 3 years

Transmission Development Plan

- The Transmission Development Plan (TDP) represents the transmission network infrastructure investment requirements
- The TDP covers a 10 year window
- Updated annually
- Indicates financial commitments required in the short to medium term


Linkages between the various plans






Strategic Grid Plan TDP 2013 – 2022 (2012 TDP)

Process for the Strategic 2040 Network Study



Generation Assumptions



Generation Scenarios

The IRP 2010 base Scenario (BASE IRP)

- IRP will be extended to 2040
- Coal will be fixed at 2030 level
- Balance in similar ratio to 2030 mix

Increased Renewables Scenario (GREEN)

- Replace nuclear component with RE base generation equivalent
- CSP (with storage) / Wind with CCV of 30% / Natural Gas


Increased Imports Scenario (IMPORT)

- Double imported power by 2030
- Reduce coal & nuclear


Mapping the Demand and Generation

- First the Demand is allocated to each Municipal Area and then summated by province to get the total Load Demand for each province
- The Bars represent the relative Demand for 2011, 2020, 2030 and 2040 with the 2040 figure shown
- Secondly the Generation is allocated to each Municipal Area and then summated by province to get the total Generation for each province for each Generation Scenario
- The Bars represent the relative Generation for 2011, 2020, 2030

LOAD GROWTH BY 2040 PER PROVINCE
(Maximum Demand in MW)




GENERATION DEVELOPMENT FOR SCENARIO A (BASE IRP)
(Maximum Demand in MW)




Mapping the Demand Balance up to 2040

- The Supply and Demand Balance value is then calculated for each Generation Scenario for each year to 2040 to determine the change over this period
- The 2011, 2020, 2030 and 2040 scenarios are presented in the report to illustrate the change over each decade
- The Bars represent the relative Demand Balance for 2011, 2020, 2030 and 2040 with the 2040 figure shown for Scenario A in this case
- All three Generation Scenarios can be mapped and compared to show the differences between the scenarios over time



Comparing Demand Balances for each Generation Scenario

DEMAND BALANCE PROGRESSION FOR EACH SCENARIO (Installed Generation less Maximum Demand in MW)




Marginal scenario difference for the TDP period

Impact of variance of wind output

- Large installed wind generation can lead to large variation in wind output
- Considered 30% & 60% output of area totals – assumed even spread
- Also considered impact of wind patterns – wind can blow from west to east zones (ABC) or east to west (CBA)
- High wind at Low Load can also impact on excess or deficit power values in areas


Wind Zones for estimating wind pattern impact




- Considered variations in wind patterns at *Peak Load* and *Low Load* to determine **the range between maximum and minimum power excess or deficit** for each scenario
- Identified the largest range variations under all scenarios to highlight areas of highest risk

MAX & MIN DEMAND BALANCE PROGRESSION CONSIDERING ALL SCENARIOS (Allocated Generation less Maximum Demand in MW)


2011




2030




2020



2040




Legend



Analysis of Demand Balance Results – all scenarios

- E. Cape: Wide range due to wind variation & nuclear commitment
- Free State: Small range – no Tx issues
- Gauteng: Constant deficit – need large Tx delivery infrastructure
- KZN: Large deficit only offset by gas gen – need extra Tx infrastructure
- Limpopo: Large excess dependant on coal & int. imports – can build Tx as needed
- Mpumalanga: Reduced excess as coal reduces – Tx essentially adequate
- North West: Constant deficit – will need more Tx infrastructure
- N. Cape: Wide range due to large CSP rollout & wind variation – will need extra Tx
- W. Cape: Wide range but within a 5GW excess or deficit range – Tx target



Main Observation

The Cape provinces pose the highest risk in terms of future Tx needs – very scenario dependant – therefore opportunity to accommodate or limit power transfer ranges with good and appropriate generation strategies.

- Eskom Grid Planning undertook a study to determine the available connection capacity for new generation at Transmission substations in the Cape area for the integration of renewable energy generation.
(Note that Transmission refers to voltages > 132kV)
- The objective of the study was to determine how much generation could be connected at each substation based on the expected 2012 network under three conditions:
 - **Level 1: (As quickly as possible – REBID)** No additional plant or lines on the transmission network to connect the generation at the 132kV busbars of the substations
 - **Level 2: (Targeted projects: 2014 - 2018)** Localised Transmission network extension to collect the potential generation at 275kV or 400kV and connect to existing Transmission substations
 - **Level 3: (Strategic)** Potential future generation connection capacity with the extension of the Transmission Grid including main corridors in the longer term beyond 2018.

The following clarifications are presented:

- Generation Connection Capacity Assessment (GCCA) - 2012 (Steady State and Dynamic) completed determining the existing network capacity.
 - All RE generation for the REBID or otherwise will be connected at distribution level, i.e. at 132kV or lower.
 - This means that security of supply is only N-0 not N-1 as this is the distribution standard.
 - Once the power reaches a transmission level substation only then it is on a N-1 system.
 - If a N-1 level of supply is requested by the generator then they will have to pay for a second direct connection with sufficient capacity to the transmission substation.
- GCCA-2016 (Steady State) completed and currently being validated with the TDP to determine network capacity
- GCCA-2016 (Dynamic) to be completed by Quarter 4 2012.

Renewable generation will be integrated into the transmission grid at distribution voltage levels (132kV or lower)


The collated output from multiple generation sources are then transported on the transmission grid



The output from the distributed farms are collected at the distribution substation




Individual turbines are widely distributed and the output needs to be collected




Generation Mix and Renewable Energy Resource Map

Applications received till March 2012

Technology	MW (Max)	%
Landfill	13	0.0%
CPV	30	0.1%
Biotherm	36	0.1%
Biogas	51	0.1%
Hydro	122	0.4%
Biomass	229	0.7%
Gas	332	1.0%
Steam	350	1.0%
Co-Gen	373	1.1%
CSP	1534	4.5%
Coal	4870	14.3%
PV	9606	28.1%
Wind	16615	48.6%
	34160	100%




SOLAR CSP GENERATION AREAS



WIND GENERATION AREAS




Renewable Generation Application




Details of Level 2 Study – relative size of applications

Renewable Generation Application




Details of Level 2 Study – cumulative size of applications

Transformation Substations 80km Buffer




Details of Level 2 Study – cumulative size of applications

Transformation Substations 80km Buffer




Details of Level 2 Study – cumulative size of applications

Sum of Application in Transformation Substations 80km Buffer




Details of Level 2 Study – require Tx TDP strengthening to enable REBID connections

Accelerate Expansion of Transformation Substations 80km Buffer



Increase & Investigate Existing Network Transformation Access





- The TDP assumptions cater for all scenarios within the TDP time frame
- Short listed REBID renewables are included in the TDP and the remainder of IRP renewables are diversified and allocated
- GCCA 2012 stability studies concluded
- GCCA 2016 to be concluded Q4 2012 release Q1 2013
- GCCA 2012 – Level 2 analysis and project initiated

A decorative graphic on the left side of the slide. It features a large, light blue curved shape that frames two circular images. The top circle shows a white wind turbine against a clear blue sky. The bottom circle shows a sunset or sunrise over a landscape with mountains, with a bright sun low on the horizon. The circles are surrounded by several thin, overlapping white lines.



Transmission Development Plan TDP 2013 – 2022 (2012 TDP)

- **The purpose of the transmission system is to optimally and reliably transport the power from the source of generation to the location of the load**
- **Role of Transmission System Planner (TSP) is in accordance with the Eskom Transmission License issued by NERSA. TSP is required to conduct the following activities for the *electricity supply industry*:**
 - To plan and augment the Transmission System
 - Planning and augmentation to be in accordance with the Grid Code
 - Customer connections to take place subject to a connection agreement
 - Compliance monitoring is part of the Eskom Transmission license
- **Network Code of SAGC specifies the following for transmission planning**
 - ***Technical criteria***
 - Voltage and thermal limits, **reliability criteria (N-1)**, generation integration, etc.
 - Generator connection conditions (Protection, Islanding, Governing, Black Start, etc.)
 - Connection conditions for generators, distributors and end-use customers (Protection, Power Factor, Fault Levels, etc.)
 - ***Planning Process***
 - ***Investment Criteria***

Network Reliability: Unfirm Electricity Supply (N-0)




Network Reliability: Firm Electricity Supply (N-1)



Assumed Demand Forecast and Comparisons


Demand Forecasts(Comparisons)




	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022
2010 IRP High Demand (MW)	40629	42027	43839	45255	47124	48479	51090	53276	55573	57649	59885	61932
2010 IRP Low Demand (MW)	39319	40002	41040	41669	42666	43157	44710	45815	46952	47848	48828	49596
2012 TDP Growth (%)		2.7%	3.8%	4.1%	3.5%	3.0%	4.8%	3.0%	1.7%	2.1%	4.6%	1.9%
2012 TDP Demand (MW)	40900	42000	43600	45400	47000	48400	50700	52200	53100	54200	56700	57800
2011 TDP Demand (MW)	40700	43400	44800	46600	47800	49200	50700	52100	52600	54700	55700	56600
2010 IRP Moderate Demand (MW)	39956	40995	42416	43436	44865	45786	47870	49516	51233	52719	54326	55734

Assumed Distributed Incremental Load Growth (2013 to 2022)


Province	Provincial Inc Load Growth (MW) 2013 – 2022
Eastern Cape	1117
Free State	226
Gauteng	3265
KZN	2367
Limpopo	1570
Mpumalanga	2368
North West	630
Northern Cape	997
Western Cape	1081





- The above assumptions are based on the IRP 2010-2030 in terms of the planned generation in the next 10 years

Assumed Generation Pattern




Summary of Transmission Infrastructure Requirements over the TDP Period

Transmission Assets	New Assets expected in 2013-2017	New Assets expected in 2018-2022	Total New Assets expected
Total kms of line	7,610	5,123	12,733
HVDC	0	0	0
765kV Lines (km)	1,890	1,810	3,700
400kV Lines (km)	5,668	2,963	8,631
275kV Lines (km)	52	350	402
Total installed Transformer MVA	59,365	24,360	83,725
Transformers (no. of)	115	50	165
Capacitors (no. of)	20	6	26
Reactors (no. of)	30	21	51


Cumulative Transformer Requirements

TDP 2011 vs TDP 2012 Cumulative Trf MVA Requirements




	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022
Actual Installed	1630	5940	2525										
2011 TDP	2050	3975	6605	14855	27645	28145	47375	63545	70160	72960	76960	77960	
2012 TDP			3130	6630	10315	18865	32805	62495	73560	77000	79625	83440	86855
Actual Installed Accumulated	1630	7570	10095										
							Year						


Transmission Plan Overview




Transmission Connection Requirements: DoE RE Program 1 & 2 - (Successful Bidders)



Transmission Assumptions based on IRP and applications received for RE



Transmission Projects Implementation Schedule




	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
Net Total Deficit	1	11	32	48	53	46	46	24	29	20	1	11	6	2	-2	0	0	0
Completed Projects	0	0	8	13	17													
Substations (Expected Date)	0	0	0	1	3	7	16	28	39	44	65	66	68	69	70	81	81	81
Lines (Expected Date)	0	0	0	0	11	23	28	47	60	78	90	98	109	116	125	128	128	128
Net Substations Deficit	0	2	8	16	20	22	17	10	6	6	0	0	1	0	0	0	0	0
Net Lines Deficit	1	9	24	32	33	24	29	14	23	14	1	11	5	2	-2	0	0	0
Total (Required Date)	1	11	32	49	67	76	90	99	128	142	156	175	183	187	193	209	209	209
Total (Expected Date)	0	0	0	1	14	30	44	75	99	122	155	164	177	185	195	209	209	209

A decorative graphic on the left side of the slide. It consists of two overlapping circular frames. The upper frame shows a white wind turbine against a clear blue sky. The lower frame shows a sunset or sunrise over a landscape with mountains, with a bright sun low on the horizon. The frames are surrounded by several thin, concentric, hand-drawn style lines in a light brown or tan color. A large, curved, light blue shape is visible in the top-left corner of the slide, and a thin, curved line extends from the bottom-left corner towards the center.

2013 - 2022


Mpumalanga Province Expansion Drivers

Mpumalanga Demand Growth Graph




CLN	Percent Growth	2013 (MW)	2018 (MW)	2022 (MW)
Highveld North (Witbank)	3.47%	2223	2806	3385
Highveld South (Ermelo)	6.24%	1430	2051	2081
Lowveld (Nelspruit)	6.86%	763	1221	1319


CLN % Contribution to 2022 Load




Mpumalanga, CLN % Load Growth and 2022 Loads



Mpumalanga Province: Development Plan



Mpumalanga Province: Development Plan




Mpumalanga Province Major Infrastructure Additions

Transmission Assets for Mpumalanga Province	New Assets expected in 2013-2017	New Assets expected in 2018-2022	Total New Assets expected
Total kms of line	711	92	803
765kV Lines (km)	0	0	0
400kV Lines (km)	709	92	801
275kV Lines (km)	2	0	2
Total planned Transformer MVA	6,975	2,300	9,275
Transformers (no. of)	15	4	19
Capacitors (no. of)	3	0	3
Reactors (no. of)	0	0	0

Mpumalanga Province Distribution Plan (Summary)

Legend

- Existing HV/MV substations to be upgraded
- New HV/MV substations
- - - New Sub Transmission Lines
- 400kV Line
- 275kV Line
- 132kV Line
- 88kV Line



Summary of Physical Quantities

		HV Lines (km)	MV Lines (km)	Transformer Capacity (MVA)
Commissioning year	2013/14	83	120	50
	2014/15	259	339	170
	2015/16	307	530	780
	2016/17	194	48	200
	2017/18	132	545	220
	2018/19	172	115	120
	TOTAL	1,146	1,696	1,540

Limpopo Province Profile




- **Generation**
 - Power Station = Matimba – (Medupi in progress)
 - MW installed = 3690MW
- **Transmission**
 - Load demand = 3068MW
 - Number of MTS = 9
 - Number of CLNs = 4
- **Distribution**
 - Economic activity = Mining (30%), Industrial (30%), Re-distributors (10%), Commercial (5%), Agricultural (5%) & Residential (20%).
 - Geographic area = Lephalale, Bela Bela, Polokwane, Thohoyandou & Phalaborwa,
- **General**
 - Economic mix - Platinum mining, Coal, high concentration of Electrification, Game Farms, Industrial, Farming, Residential & Commercial, International Tie Line - Botswana

Limpopo Province Network Expansion Drivers




Limpopo Demand Growth Graph




CLN	Percentage Growth	2013	2018	2022
Waterberg	4.92%	534	704	865
Lowveld North	6.25%	1112.9	1528	1713
Warmbad	4.17%	329.5	424	456
Polokwane	4.80%	1328.5	1582	1842


Limpopo CLN % Contribution to 2022 Load



CLN % Load Growth and 2022 Loads




Limpopo Province: Development Plan



Limpopo Province Major Infrastructure Additions


Transmission Assets for Limpopo Province	New Assets expected in 2013-2017	New Assets expected in 2018-2022	Total New Assets expected
Total kms of line	2,260	730	2,990
765kV Lines (km)	900	0	900
400kV Lines (km)	1,360	580	1,940
275kV Lines (km)	0	150	150
Total planned Transformer MVA	7,770	500	8,270
Transformers (no. of)	13	2	15
Capacitors (no. of)	0	0	0
Reactors (no. of)	4	2	6

Limpopo Province Distribution Plan (Summary)




North West Province Expansion Drivers

North West Province Demand Growth Graph




	Percentage Growth	2013 (MW)	2018 (MW)	2022 (MW)
Rustenburg	2.93%	1713	2252	2256
Carletonville	0.72%	1433	1484	1521


CLN % Contribution to 2022 Load



North West, CLN Load Growth and 2022 Loads



North West Province: Development Plans



North West Province Major Infrastructure Additions


Transmission Assets for Northern West Province	New Assets expected in 2013-2017	New Assets expected in 2018-2022	Total New Assets expected
Total kms of line	566	225	791
765kV Lines (km)	0	0	0
400kV Lines (km)	566	225	791
275kV Lines (km)	0	0	0
Total planned Transformer MVA	12,250	315	12,565
Transformers (no. of)	14	1	15
Capacitors (no. of)	4	0	4
Reactors (no. of)	2	1	3

North West Province Distribution Plan (Summary)



Legend

- New Main Transmission Substation
- Existing HV/MV substations to be upgraded
- New HV/MV substations
- - - New Sub Transmission Lines
- 400kV Line
- 275kV Line
- 132kV Line
- 88kV Line



		HV Lines (km)	MV Lines (km)	Transformer Capacity (MVA)
Commissioning year	2013/14	133.4	345	200
	2014/15	198	295	220
	2015/16	366.2	454	450
	2016/17	150.2	484	380
	2017/18	343.4	286	240
	2018/19	139.66	234	190
	2019/20	104	105	80
TOTAL		1,586	1,743	2,045


Gauteng Province Profile



- **Generation**
 - Power Stations = 600MW (Kelvin PS)
- **Transmission**
 - HV / DC converter station = 1800MW
 - Load demand = 12 403MW
 - Number of MTS = 35
 - Number of CLNs = 6
 - No. of Tx lines = 72
 - Km of Tx lines = 2 501km
- **Distribution**
 - Economic activity - Industrial (1.7%), Mining (1.5%), Commercial (10%), Residential (9.8%), Agricultural (1.9%) & Re-distributors (75.1%)
 - No. customers served = 757 000
 - Number of substations = 562
 - Km of Dx lines = 25 000km
 - Geographic area = Nigel, Vaal Triangle, West Rand, Johannesburg, Pretoria and Warmbad
- **General**
 - Economic Mix: Re-distributor, Gold mines and Commercial, SCAW Metal, SAPPI, SASOL, Natref, Anglo Coal


Gauteng Province Expansion Drivers

Gauteng Demand Growth Graph




	Percentage Growth	2013 (MW)	2018 (MW)	2022 (MW)
Johannesburg	2.90%	4974	5887	6480
West Rand	2.20%	2100	2435	2672
Nigel	1.68%	1709	1791	1868
Vaal Triangle	1.37%	1859	1977	2139
Pretoria	3.02%	2236	2543	2985
Warmbad	4.17%	329	424	456


Gauteng CLN % Contribution to 2022 load



Gauteng CLN % Load Growth and 2022 Loads



Transmission Development Plan – Gauteng Province



1. Increase Capacity and Reliability:

- Address current network thermal constraints
- To increase transfer of power

2. Network System Integration:


- New 400kV into 275kV

3. Strategic Network Establishment:

- Convert the existing 275kV networks to 400kV
- Acquire strategic power corridor routes into major cities

4. Challenges:


- Servitude acquisitions




Gauteng Province Major Infrastructure Additions

Transmission Assets for Gauteng Province	New Assets expected in 2013-2017	New Assets expected in 2018-2022	Total New Assets expected
Total kms of line	813	91	904
765kV Lines (km)	0	0	0
400kV Lines (km)	763	59	822
275kV Lines (km)	50	32	82
Total planned Transformer MVA	5,390	5,215	10,605
Transformers (no. of)	16	13	29
Capacitors (no. of)	6	0	6
Reactors (no. of)	0	0	0

Gauteng Province Distribution Plan (Summary)






- **Generation**
- Lethabo Power Station
- Generation: 3 558 MW
- **Transmission**
- Load demand = 1 859MW
- Number of MTS = 11
- Number of CLNs = 4
- **Distribution - Free State Region**
- Economic activity = Mining (3.2%), Industrial (3.4%), Re-distributors (76.4%), Commercial (3.9%), Agricultural (4.4%), Prepayment (3.2%), Residential (1.3%), Traction (0.8%) & International (3.4%).
- No. customers served = 233 115
- Number of substations = 284
- Geographic area: Bethlehem, Bloemfontein, Welkom
- Total km's of line (Dx & Tx) = 44 480 km


Free State Province Expansion Drivers

Free State Demand Growth Graph




	Percentage Growth	2013	2018	2022
Bloemfontein	3.14%	486.6	615	649
Welkom	0.57%	848.7	874	893
Kimberly	1.72%	181.6	191	198
Carletonville	0.18%	290.8	293	295

Free State CLN % Contribution to 2022 Load




Free State, CLN % Load Growth and 2022 Loads



Free State Province: Development Plan


TRANSMISSION DEVELOPMENT PLAN 2013 - 2022 FREE STATE PROVINCE



Free State Province Major Infrastructure Additions


Transmission Assets for Free State Province	New Assets expected in 2013-2017	New Assets expected in 2018-2022	Total New Assets expected
Total kms of line	110	663	773
765kV Lines (km)	0	430	430
400kV Lines (km)	110	233	343
275kV Lines (km)	0	0	0
Total planned Transformer MVA	250	1,000	1,250
Transformers (no. of)	1	3	4
Capacitors (no. of)	0	2	2
Reactors (no. of)	0	7	7

Free State Province Distribution Plan (Summary)



Year	HV Lines (km)	MV Lines (km)	HV Trfr capacity (MVA)
2013/14	0	31	0
2014/15	82	361	335
2015/16	415	512	444
2016/17	276	341	296
2017/18	394	462	228
2018/19	263	308	152
Total	1430	2015	1455


KwaZulu-Natal Province Background



- **Generation**
 - Drakensberg Pumped Storage with 1000MW installed capacity
- **Transmission**
 - Load demand = 6 784MW
 - Number of Substations = 21
 - Number of CLNs = 4
- **Distribution**
 - Economic activity - Re-distributors (80.6%), Commercial (5.1%), Mining (1%), Industrial (3%), Residential (3.6%) & Agriculture (2.9%), Prepayment (3.3%), Traction (0.5%)
 - Number of substations = 443
 - Km of lines (incl. Transmission) = 56 610 km
- **General**
 - Economic mix - Mining, Agriculture (Sugar Cane & Timber), Residential, Commercial & Industrial.


KwaZulu-Natal Province Expansion Drivers

Demand Growth




CLN	Ave. Annual Growth (%)	2013	2018	2022
		(MW)		
Ladysmith & Newcastle	2.85	1351	1568	1750
Empangeni (incl. Richard's Bay)	2.16	2090	2439	2594
Pinetown (incl. Pmb, Dbn)	3.64	3603	4148	5068

CLN % Contribution to 2022 Load



CLN % Load Growth and 2022 Loads




1. Increase in Capacity

- Ingula Power Station - A pumped-storage scheme that is under construction, spanning the escarpment of the Little Drakensberg straddling the provincial boundary of Free State and KwaZulu-Natal within the Ladysmith CLN. Ingula will have a generating capacity of 1 330 MW.

2. Network System Integration

- **KZN 765kV Strengthening** - Establishing 765kV in the Pinetown and Empangeni areas which will run from the power pool in the north and integrating it into the 400kV network in both areas.
- **South Coast Strengthening** - Construction of a 2nd 400kV line from Ariadne (near Pietermaritzburg) to Eros (in Harding) and a 400kV line from Eros to a new Vuyani substation (in Mthatha) to address the electrification load demand along the KZN south coast towards the Eastern Cape Province.
- **eThekweni Electricity Network Strengthening** - Extension of Umgeni substation (in New Germany) to include 275/132kV transformation and firming up the 275kV supply into Ottawa Substation (near Veralum).


KwaZulu-Natal Province TDP Overview



KwaZulu-Natal Province Major Infrastructure Additions

Transmission Assets	2013-2017	2018-2022	Total
765kV Lines (km)	80	300	380
400kV Lines (km)	505	450	955
275kV Lines (km)	0	68	68
Total Lines (km)	585	818	1,403
Transformers (no. of)	9	5	14
Capacitors (no. of)	0	0	0
Reactors (no. of)	1	6	7

KwaZulu-Natal Province Distribution Plan (Summary)



Eastern Cape Province Profile



Transmission Network

- Geographic Area = Nelson Mandela Metro, East London, Buffalo City Metro, Mthatha
- Number of CLNs = 2
- Number of Substations = 9
- Load demand = 1 627 MW

Distribution

- No. customers served 638 187
- Load Composition:
 - Residential - 37%, Commercial - 20%, Industrial - 34%, Agricultural - 6%, Traction - 3%
- Number of Substations ≈ 173
- Length of lines ≈ 40 147km

Generation in Eastern Cape


- Gariep 4x90MW
- Port Rex 3x57MW
- Distribution Embedded Hydros

General

- Economic Mix – Motor vehicle assembly industry, light industry and foundry, textiles, farming, residential and commercial


Eastern Cape Province Load Forecast

Eastern Cape Demand Growth Graph




	Percentage Growth	2013 (MW)	2018 (MW)	2022 (MW)
East London	4.15%	685.3	791	877
Port Elizabeth	7.70%	1042	1556	1967

Eastern Cape CLN % Contribution to 2022 Load



Eastern Cape, CLN % Growth and 2022 Loads



1. Resolve current constraints:


- Electricity Infrastructure in the Mthatha Area is depleted and barely meet required reliability levels
- Integrate the KZN and East London system to enhance reliability

2. Meet the anticipated load demand:


- Load in both CLNs anticipated to increase particularly around the Coega IDZ

3. Integrate renewable energy:

- Significant Renewable Energy interest in response to Government Renewable programme (mainly wind)



Eastern Cape Province: Development Plan



Eastern Cape Province Major Infrastructure Additions


Transmission Assets for Eastern Cape Province	New Assets expected in 2013-2017	New Assets expected in 2018-2022	Total New Assets expected
Total kms of line	886	541	1,427
765kV Lines (km)	350	350	700
400kV Lines (km)	536	191	727
275kV Lines (km)	0	0	0
Total planned Transformer MVA	6,080	2,215	8,295
Transformers (no. of)	11	7	18
Capacitors (no. of)	4	3	7
Reactors (no. of)	3	1	4

Legend

- New HV/MV Substations
- Existing HV/MV Substations to be Upgraded
- ✕ Proposed Substations dismantle
- - - Proposed 765kV Powerline
- - - Proposed 400kV Powerline
- - - Proposed 132kV Powerline
- - - Proposed 66kV Powerline
- - - Proposed Powerline dismantle


HV Lines

- 400.0 [kV]
- 220.0 [kV]
- 132.0 [kV]
- 66.00 [kV]



Commissioning Year	HV Lines (km)	MV Lines (km)	Transformer Capacity (MVA)
2013/14	332	270	330
2014/15	446	340	585
2015/16	530	150	240
2016/17	207	125	100
2017/18	189	110	100
2018/19	68	100	80
TOTAL	1772	1095	1435

Western Cape Province Profile



Generation

- 1 nuclear, 3 gas power stations, 1 pumped storage
- 4 471 MW generation capacity
- 11% of total Eskom generation capacity

Transmission

- 4205MW (Regional peak)
- Number of MTS = 13
- Number of CLNs = 3

Distribution


- Customers connected =324 000
- Substations =269
- Geographical area: George, Bellville, Koeberg

General

- Economic mix: Commercial (67%)
- Mining (15%), Agriculture (18%)


Western Cape Province Expansion Drivers

Western Cape Demand Growth Graph




	Percent Growth	2013	2018	2022
West Coast (Vredendal)	1.55%	474.3	519	543
Southern Cape (Riversdale)	2.66%	945	1052	1157
Peninsula (Cape Town)	3.61%	3218.1	3717	4018


CLN % Contribution to 2022 Load



CLN % Load Growth and 2022 Loads



Western Province: Development Plan




Western Cape Province Major Infrastructure Additions

Transmission Assets for Western Cape Province	New Assets expected in 2013-2017	New Assets expected in 2018-2022	Total New Assets expected
Total kms of line	590	943	1,533
765kV Lines (km)	560	560	1,120
400kV Lines (km)	30	383	413
275kV Lines (km)	0	0	0
Total planned Transformer MVA	9,660	7,000	16,660
Transformers (no. of)	16	11	27
Capacitors (no. of)	0	0	0
Reactors (no. of)	15	4	19

Western Cape Province Distribution Plan (Summary)


		HV Lines (km)	MV Lines (km)	Transformer Capacity (MVA)
Commissioning year	2013/14	189	203	860
	2014/15	105	128	339
	2015/16	201	154	832
	2016/17	210	135	465
	2017/18	114	120	333
	2018/19	94	119	295
	TOTAL	913	859	3124



Legend

- Existing 132kV/MV substations
- Existing 66kV/MV substations
- Existing 132kV Line
- Existing 66kV Line

Northern Cape Province Profile



Generation

- Vanderkloof Power Station is located at the Vanderkloof Dam wall.
- It has a generating capacity of 240 MW (2 x 120 MW) into the Eskom Grid.

Transmission

- 681MW (Regional peak)
- Number of MTS = 16
- Number of CLNs = 5

Distribution

- Customers connected = 67 601
- Substations = 191


- Geographical area: Kimberley, Upington and Namaqualand, 15 Customer Network Centres from Springbok, Calvinia, De Aar to Jan Kemsdorp.

General

- Economic mix: Commercial (21%), Mining (52%), Agriculture (27%)


Northern Cape Province Expansion Drivers

Northern Cape Demand Growth Graph




	Percent Growth	2013 (MW)	2018 (MW)	2022 (MW)
Namaqualand	7.47%	136.3	263	266
West Coast	1.03%	12.1	13	13
Kimberley	16.31%	406.8	981	1247
Karoo	1.33%	297.9	309	325


CLN % Contribution to 2022 Load



Northern Cape, CLN % Load Growth and 2022 Loads



Northern Cape Province: Development Plan




Northern Cape Province Major Infrastructure Additions

Transmission Assets for North Cape Province	New Assets expected in 2013-2017	New Assets expected in 2018-2022	Total New Assets expected
Total kms of line	1,089	1,290	2,379
765kV Lines (km)	0	440	440
400kV Lines (km)	1,089	750	1,839
275kV Lines (km)	0	100	100
Total planned Transformer MVA	5,445	1,815	7,260
Transformers (no. of)	20	4	24
Capacitors (no. of)	3	1	4
Reactors (no. of)	6	4	10

Northern Cape Province Distribution Plan (Summary)


Summary of Physical Quantities

		HV Lines (km)	MV Lines (km)	Transformer Capacity (MVA)
Commissioning year	2013/14	14	81	90
	2014/15	126	131	300
	2015/16	159	12	110
	2016/17	159	58	105
	2017/18	114	20	36
	2018/19	0	6	40
	TOTAL	572	308	681





Refurbishment and Strategic Spares Principles and Plan




- Eskom project life cycle model to be followed.
- Investment justifications to be based on following criteria:
 - Statutory
 - Strategic
 - Least Economic Cost
 - Operating Cost Reduction
- Assets to be refurbished in accordance with asset life-cycle management plans (LCMPs).
- Condition, criticality & risk assessment (CCRA) principles to be used for refurbishment investment decisions. (Likelihood of asset loss vs. criticality of the asset to the network)

Complying to the Wires Business PLCM

Wires Standard Projects Process

Project Definition Readiness Assessments (PDRA)



Planning or Originator's Report (per project)	Approved SURS	Acquired servitudes	Constructed /Refurbished Asset	Contracts closed out
User Requirements	Approved Asset Specification	EMP Submission	Asset in CO	Project Closed out
Refurb Plan	SLD	Detailed Eng Design	As built drawings	Review meetings held
Expansion Plan	Station Layout	Project Execution Plan		
Plans Costed & Prioritised	Conductor & Tower selection			

Key Deliverables per Phase


- The bulk of the Transmission network (>100 substations) were constructed between the years 1960 and 1980. This means that from now onwards Transmission will need to cope with substation plant, equipment and infrastructure that has been in service for 40 years and longer.
- Equipment, like the substation batteries and electronic components of protection and control systems, corroded conductors etc. are not repairable and replacement is the only option and is essential to sustain the Tx network.
- “Aged” equipment like CTs, VTs, Surge Arresters, H.V. Circuit Breakers and Power Transformers apart from the risk of supply interruptions also can fail violently and poses a safety risk to staff. These need to be removed from the system, if identified as a risk, and can not always be run to failure.
- Grid Code and the Transmission Licence require certain performance and quality standards, where plant and equipment do not meet these requirements, replacement or upgrading is required.
- Deferring investments in replacing “aged” equipment will:
 - increase maintenance requirements
 - Increase emergency repairs
 - Overall result is higher operating expenditure and unplanned maintenance costs

- Combine refurbishments with expansion
- Corridor refurbishments
- Substation refurbishments
- Bay refurbishments (e.g. transformers)
- Component refurbishments - i.e. component refurbishments are only remaining after packaging into above priorities

Refurbishment 5 Year Plan

R' millions

Categories	YE 2011	YE 2012	YE 2013	YE 2014	YE 2015	YE 2016	YE 2017	YE 2018	5Yr Total
Refurbishment	489	589	477	652	948	1,265	1,510	1,745	6,120



- The plan from and including YE 2015 is based on the expected refurbishment requirements due to the aging network
- The bulk of the transmission network will be older than 40 years within the next 10 years.
- The details of the future refurbishment projects will be identified through a structured “asset condition assessment” program.


Top Refurbishment Projects for FY14-18

No	Supply Plan Name	Current Stage	2012/13	2013/14	2014/15	2015/16	2016/17	2017/18	TOTAL FY14-18
1	Phased Replacement of High Risk TRFRS	ERA	104	101	280	111	-	-	491
2	Acacia SS : Refurbishment	DRA	-	1	25	42	48	48	165
3	ERTU REFURBISHMENT (Combined FY2010_11-FY2019/20)	ERA	7	12	37	31	39	40	158
4	Georgedale Refurb Phase 2	DRA	1	5	23	34	39	40	141
5	Gromis Oranjemond No1 220kV Line Re-conductor & replace Earthwire (ERA)	ERA	11	61	50	-	-	-	111
6	Alpha Beta 1&2 Beta Hydra 2 Foundation Ref	Pre CRA	3	15	24	20	28	28	116
7	Glockner SS Refurbishment	DRA	-	2	25	21	36	31	115
8	Apollo (AC) SS Refurbishment	Pre CRA	-	-	9	28	38	38	113
9	ABB Refurbishment Reactors	ERA	25	28	33	26	-	-	87
10	Scafell Refurbishment (Phase 2)	CRA	-	12	19	19	28	30	108
11	Muldersvlei SS Refurbishment Phase 2	DRA	0	4	11	36	44	9	105
12	VULCAN SS : REFURBISHMENT	Pre CRA	-	2	3	28	30	32	95
13	Westgate SS Refurbishment	Pre CRA	-	-	2	12	31	42	87
14	Apollo CS: HVDC Refurbishment Phs 2 (ERA)	CRA	-	-	5	5	38	38	85
15	Eiger SS Refurbishment	Pre CRA	-	0	2	14	28	38	82
16	Drakensberg Refurb GIS & supports	DRA	-	3	16	28	28	-	76
17	Apollo CS : Upgrade the Apollo DC Harmonic Filters	Pre CRA	-	0	4	7	24	40	74
18	Replacement of under creepage equipment in heavy pollution substations (Western Grid)	Pre CRA	-	3	9	19	19	18	67
19	North Grid: Anti Climb devices on Various Lines	DRA	0	3	11	14	19	19	66
20	Nevis SS Refurbishment	Pre CRA	-	-	1	9	21	34	65
	Sub Total		150	251	589	503	537	525	2,405

SS Refurbishments per Province FY14-18

GAUTENG PROVINCE	Benburg SS Refurbishment	1	FREE STATE PROVINCE		
	Brenner SS Refurbishment	1			
	Eiger SS Refurbishment	1			
	Esselen SS Refurbishment	1			
	Fordsburg SS Refurbishment	1			
	Glockner SS Refurbishment	1			
	Jupiter SS Refurbishment	1			
	Kookfontein SS Refurbishment	1			
	Nevis SS Refurbishment	1			
	Princess SS Refurbishment	1			
	Prospect SS Refurbishment	1			
	Scafell Refurbishment (Phase 2)	1			
	Westgate SS Refurbishment	1			
	Apollo (AC) SS Refurbishment	1			
Gauteng Total		14	FREE STATE Total		
KZN PROVINCE	Bloedrivier SS Refurbishment (73)	1	LIMPOPO PROVINCE	Spitskop SS Refurbishment	1
	Chivelston SS Refurbishment	1			
	Danskraal SS Refurbishment (110)	1			
	Drakensberg Refurb GIS & supports	1	Limpopo Total		1
	Georgedale Refurb Phase 2	1	EASTERN CAPE PROVINCE	Buffalo SS Refurbishment	1
	Hector SS Refurbish Kiosks	1		Grassridge 132kV Refurbishment	1
	Impala SS Refurbishment	1		Grassridge SS Refurbishment	1
	Incandu SS Refurbishment	1		Pembroke SS Refurbishment	1
	Ingagane SS Refurbishment - Phase 2	1			
KZN Total		9	Eastern Cape Total		4
MPUMALANGA PROVINCE	Komatipoort SS Refurb	1	WESTERN CAPE PROVINCE	Acacia SS : Refurbishment	1
	Kruispunt SS Refurb	1		Aurora SS Refurbishment	1
	Malelane 132kV SS Refurb	1		Bacchus SS Refurbishment	1
	Marathon SS Refurbishment	1		Muldersvlei SS Refurbishment - HV Plant	1
	Merensky SS Refurbishment	1		Muldersvlei SS Refurbishment Phase 2	1
	Prairie SS Refurbishment	1	Western Cape Total		5
	Rockdale SS Refurbishment	1	NORTH WEST PROVINCE	Hermes SS Refurbishment	1
	VULCAN SS : REFURBISHMENT	1		Watershed SS Refurbishment	1
Mpumalanga Total		8		Ararat SS Refurbishment	1
				Trident SS Refurbishment	1
			North West Total		4
			NORTHERN CAPE PROVINCE	Boundary SS Refurbishment	1
				Ferrum SS Refurbishment	1
				Helios SS Refurbishment	1
			Northern Cape Total		3
			Grand Total		48


SS Refurbishments per Province FY2014-18



Drivers for capital spares

R' millions

Categories	YE 2011	YE 2012	YE 2013	YE 2014	YE 2015	YE 2016	YE 2017	YE 2018	5Yr Total
Capital Spares	441	374	484	466	244	129	119	119	1,078



- From 2013 we will be fulfilling the spares policy in accordance with the increase in the installed transformer base.
- From 2015 onwards, majority of provisions are for stores replenishments.
- High risk transformer replacement project will assist in reducing replenishment numbers.
- From 2017 onwards, all stations to be firm (n-1), reducing risk & dependence on capital spares.

A decorative graphic on the left side of the slide. It consists of two overlapping circular frames. The upper frame shows a white wind turbine against a clear blue sky. The lower frame shows a sunset or sunrise over a landscape with mountains, with a bright sun low on the horizon. The frames are surrounded by several thin, concentric, hand-drawn style lines in a light brown or tan color. A large, curved, light blue shape is visible in the top-left corner of the slide, and a thin, curved line extends from the bottom-left corner towards the center.

2013 - 2022

- **Asset Management Philosophy**
 - Life Cycle management of assets
 - Ageing infrastructure
 - Strategic Spares to ensure minimum requirements are met
 - Our historical underinvestment as related to benchmarked refurbishment levels
 - Specialised equipment to enable optimised outage management i.e. live line equipment
 - Physical Site Security and Monitoring
- **Ensuring the adequacy and security of the existing network installation**
 - To ensure existing customer base continues to have a secure supply and enable continued growth in these areas

- Strategic Servitude Acquisitions
- Funding requirements for new customer connections
- Network Strengthening
 - Minimum Grid Code Requirements set
 - Ensure reliability and security of supply
- New Generation Connections
 - To ensure the evacuation and transportation of power to the load centres
 - To facilitate construction supplies for the new power stations and for auxiliary supplies

10 Year Transmission Capex Summary Excluding IDC

Categories	FY13-22 (Rm)
Capacity Expansion	149,259
Refurbishment	12,194
Capital spares	2,349
EIA and servitudes	4,696
Strategic	1,749
Production Equipment	4,537
Total	174,763

5 Year Distribution Capex Summary Excluding IDC

Categories	FY14-18 (Rm)
Direct Customers	13 130
Refurbishment	11 966
Strengthening	24 826
Reliability Capex	3 091
Asset Purchases	1 988
Eskom Funded	55 001
Electrification (DoE Funded)	9 766
Total	64 767

- The most visible difference between this TDP and the previous year's TDP is the increase in the amount of transformation (MVA) by approximately 11000MVA. This is mainly due to new substations being added in the latter part of the planning period.
- There is a marginal change in the net amount of lines (km) required. More kilometres of line have been added in the new planning period.
- There has been re-phasing of the existing projects using more realistic completion dates.
- Projects required for the DOE Renewable Energy (RE) IPP program that are in budget quote phase have been added. There still remains an assumed plan for RE integration that is the same as last year's plan.
- The resultant is an improved and more realistic or achievable spread of the transmission line projects and transformer installations. The result of the slower rate of completion of the transmission lines and new transformers increases the overall risk to the network.
- The conclusion is that the transmission projects in this TDP (all projects) will result in the overall network becoming Grid Code compliant, while catering for increased load growth and integration of new generation.

Thank you

