

A decorative graphic on the left side of the slide, consisting of four overlapping circular frames. The top frame shows a person working at a computer with a green data visualization. The middle frame shows a large, modern white building with a central tower. The bottom frame shows a city skyline at night with a prominent tower. The bottom-most frame shows a high-voltage power line tower against a blue sky with white clouds.

The Eskom Transmission Development Plan (TDP) 2023 - 2032

27 October 2022

08:30 - 09:00	Join MS Teams Live Event	All
09:00 - 09:05	Opening and welcome	Popi Njapha Chief Engineer: Grid Planning
09:05 - 09:15	Keynote address	Segomoco Scheppers Managing Director: Transmission
09:15 - 09:30	TDP 2022 Overview / Setting the Scene	Makoanyane Theku Senior Manager: Customers and Grid Connection
09:30 - 10:00	Transmission Demand Assumptions, Analysis and Impact of Renewables	Ronald Marais Senior Manager: Strategic Grid Planning
10:00 - 10:15	System Operations Implications on Ancillary Services	Siju Joseph Manager: Ancillary Services
10:15 - 10:30	Grid Assets Refurbishment Plans	Calvin Govindasamy Chief Engineer: Asset Investment Planning
10:30 - 10:40	Comfort Break	All
10:40 - 11:50	Provincial Development Plans (Northern & Southern Grids)	Caroleen Naidoo / Thokozani Bengani Chief Engineer: Grid Planning
11:50 - 12:00	TDP 2022 Summary	Leslie Naidoo Senior Manager: Grid Planning
12:00 - 12:10	Comfort Break	All
12:10 - 12:20	TDP Delivery Interventions	Prince Moyo General Manager: Asset Management
12:20 - 12:30	TDP Project Schemes in Execution	Naresh Singh General Manager: Transmission Projects Delivery
12:30 – 13:00	General discussion (Q&A) and Closure	All



Keynote Address

Segomoco Scheppers
Managing Director: Transmission




Setting-the-scene

Makoanyane Theku
Senior Manager: Customers & Grid Connection

- The TDP is a Transmission **licence** requirement that emanates from the **Grid Code** which states that “The *NTC* shall annually publish a minimum five-year-ahead *TS* development plan by end October, indicating the major capital investments planned (*but not necessarily approved*).”
- The **key change** from last year’s TDP 2021 is associated with the **new generation capacity assumptions**. While the TDP 2021 focused predominantly on the Integrated Resource Plan (IRP) 2019 for these assumptions, the TDP 2022, apart from the IRP 2019, also factored in the following:
 - Eskom’s 2035 Corporate Strategy,
 - Connection applications received through the various DMRE procurement programmes,
 - Information obtained through consultations with RE associations, as well as,
 - Applications received from the non-DMRE integration programmes


Background to the TDP (consultative process)



The purpose of the presentation is to:

- Contextualise the planning timelines relating to the demand forecast and generation patterns
 - Share information and results relating to the integration of new generation capacity and address the future network requirements
 - Share assumptions and results from the Transmission Development Plan 2023 – 2032 for both the capacity expansion and refurbishment portfolios
 - Share information on the initiatives undertaken to implement the TDP, as well as challenges experienced on projects in execution
 - More importantly, to solicit comments and inputs to improve on the Transmission Plans
- 

Planning for the integrated power system







Recent Transmission Network Expansion Successes

Historical investments in the Eskom power system: 8.1 GW of generation, ~ 4347 km of transmission lines, and ~19 GVA of transformation capacity


Generation Integration (MW)



Transmission lines (km)



Transmission Substations (MVA)



DMRE IPP programme overview – end Sept 2022



Peakers	REIPP BW1	REIPP BW2	REIPP BW3&3.5	REIPP BW4&4B	RMIPPP	REIPP BW5	REIPP BW6++
2 projects 1005 MW	28 projects 1415 MW	19 projects 1033 MW	18 projects 1628 MW	26 projects 2205 MW	11 projects ~2000 MW	25 projects ~2583 MW	TBA projects ~5200 MW
All projects connected	All projects connected	All projects connected.	17 projects connected, 1 project in execution phase	25 projects connected, and 1 in execution phase	11 preferred bidders. 3 Projects currently in construction (150MW - PV with BESS)	25 preferred bidders. 3 PPAs signed so far. FC expected by Dec 22/Jan 23 for these projects	BW6 bid submissions received, to be evaluated. Storage, Gas proposals in planning phase

Up to BW5: ~12 GW from ~ 129 individual projects

91 projects totalling 7110 MW have been commissioned, of which 6105 MW is from RE Sources

- Eskom has committed Capital to enable the integration of successful bidders (Bid Windows 1 – 5) to the National Grid.
- Beyond BW5, the Transmission network capacity in the Western, Eastern and Northern Cape regions is severely constrained / limited and would require substantial strengthening at local and corridor level to provide additional network capacity to integrate the RE plants to the system.

Apart from the usual TDP assumptions and provincial plans that we normally share at the public forum, today's presentation also includes:

- 1) Implications to ancillary services by our System Operator
- 2) Initiatives undertaken to deliver on the TDP implementation
- 3) Experiences related to projects in execution

I hope you find today's engagements fruitful and we look forward to your feedback!!


A decorative graphic on the left side of the slide. It consists of several overlapping circular frames. The top frame shows a white wind turbine against a blue sky. The bottom frame shows a sunset over a landscape with hills. The frames are connected by a curved line that starts at the top left and ends at the bottom left.

The TDP 2023 - 2032 Assumptions on the Demand and Generation Forecast


Ronald Marais

Senior Manager: Strategic Grid Planning

TDP process overview



National Demand Forecasts (GW) at Time of System Peak shown with the 2022 forecast, for the TDP period 2023 -2032 with six scenarios, Tx High, Tx Moderate, Tx Medium EE, Tx Low and Constrained 1 & 2




*Instantaneous Peak Demand



	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
2022 Tx High							35	35	36	37	38	39	40	41	42	44	45	46
2022 Tx Moderate High							35	35	36	36	37	38	38	39	40	41	42	43
2022 Tx Medium EE / EI							35	33	34	34	34	35	35	36	36	37	37	38
2022 Tx Low							35	33	33	33	33	33	33	34	34	34	34	34
2021 Tx High							35	35	36	37	38	39	40	41	43	44	46	47
2021 Tx Moderate High							35	34	35	35	36	37	38	39	40	41	42	43
Actual Peak Demand (GW) *	34.6	35.6	36.4	36.4	35.0	34.2	34.7											
Constrained Scenario 1							35	32	33	33	36	38	39	39	40	41	42	43
Constrained Scenario 2							35	33	32	32	31	34	37	39	40	41	42	43

- The forecast has been revised down due to lack of gen capacity, Covid-19 effects, and sustained economic downturn
- The Tx Moderate High Forecast will be used for planning purposes
- Because of previous higher forecasts projects affected by load will be reprioritized
- **Generation has become the primary driver of infrastructure development henceforth**





Provincial allocation of demand potential




Generation capacity forecast



Generation comparisons (TDP 2021 vs TDP 2022)




Battery Storage




Generation build-up graph


Generation Build-up Chart



How do we know where to build?



Generation spatial allocation






Spatial considerations

- The allocation of Renewables took into consideration the following:
 - CSIR view on RE potential adjusted for sensitive areas
 - Maximum PV potential in a 60km radius
 - EIA applications in the past few years from DEA
 - Grid Planning applications processed thus far
 - Proximity to major corridors and network
 - Relocations for earlier years due to network constraints
 - GCCA 2024 Post-BW5
 - Strengthening projects in the WC and NC



Grid stability is more than balancing supply and demand...



Inverter grid interaction has required two additional stability considerations

International grid stability inverter control interactions / resonance / oscillation

Control Interactions/Resonance/Oscillation






Figure 3 - showing the reactive power output from System 12 relative prior to the event in response to a 2% voltage step change



The effective impedance reaches the instability threshold close to the peak power output of the plant



- **Similarity to the South Africa System**



<https://www.youtube.com/watch?v=OyGCB3FV5Pw&t=1252s>


- System strength “short circuit” is declining over the entire system
- Unlike South Africa the inertia in Great Britain remains high (as was in this event)
- Low synchronous generation with high inverter penetration - System oscillations were observed by the system operator for an extended period.
- Various generation plant tripped (correctly) from the oscillation wide impact
- ROOT CAUSE UNKNOWN - Short term more synchronous generation online
- Finding the root cause requires developing more detailed EMT model.
- Identified need to update the Grid Code for improved modeling requirements

AEMO (Australia) – Large islanded network high penetration

EMT MODELS CRITICAL FOR MODERN POWER SYSTEM



7



Source: AEMO system strength workshop, <https://aemo.com.au/en/learn/energy-explained/system-strength-workshop>

<https://www.youtube.com/watch?v=U5sgMMj1lco&t=146s>




High penetration requires high resolution of modeling to observe system stability and inverter interaction

- Current transient analysis tools (RMS) are failing in high penetration inverter dominant networks.
- Under fault conditions the “RMS tend to overestimate how well things are going to be”
- RMS show system will return to a stable condition the EMT shows network will collapse.
- Greater congruence between the EMT and infield measurements.
- Analysis must shift to EMT models
- EMT needs the real source code compiled into the EMT, to better represent the interaction with the system and other inverter
- Cannot evaluate independently of other plant

- Technology Advancements – Grid-Forming Inverter NREL and ARENA perspective



<https://www.nrel.gov/docs/fy21osti/73476.pdf>



- However, similar to any dynamic device (including synchronous condensers) **they are not a 'silver bullet'** and to be effective, there are a range of factors which need to be carefully considered.
- The thoughtful deployment **of grid forming batteries alongside other technologies will be critical to managing the transition to renewables.**

<https://arena.gov.au/knowledge-bank/pscad-assessment-of-the-effectiveness-of-grid-forming-batteries/>

- Grid-Forming Inverters are critical to high penetration weak grids like South Africa
- Still under development by many manufacturers
- No international standards exist
- Manufacturers have their own interpretation of a Grid-Forming inverters

Collaboration is key to enable grid capacity

Activities underway

- Inter governmental initiatives
- Provincial
- Renewable association
- International collaboration






Questions?

Transmission System Operations Ancillary Services Implications

Siju Joseph

Manager: Transmission System Operator
Ancillary Services



(AS) Grid Code Definition


- Services supplied to the *NTC* by *generators*, *distributors* or *end-use customers*, necessary for the reliable and secure transport of power from *generators* to *distributors* and other *customers*.

Why and what services?

- The *System Operator* shall be responsible for the provision of all short-term reliability services for the *IPS*. These include restoration, the balancing of supply and demand, the provision of quality voltages and the management of the real-time technical risk.

How will this be done?


- The *System Operator* shall be responsible for procuring the required *ancillary services* as described in this section in accordance with the license and market rules. It shall state opportunities for the provision of *ancillary services*.




- **System reserves** to combat generation/load contingencies and forecast errors. These include instantaneous, regulating, ten-minute, supplemental and emergency reserves



- **Reactive power and voltage control** to maximise system security and reduce network losses,
- **Constrained generation** to compensate those generators dispatched out of the merit order and suffer financial loss due to lack of related market rules dealing with transmission constraints and units in strategic positions.
- **System restoration** services to expedite system restoration resulting from regional and system-wide interruption of supply. These include Black-start, Islanding and in future self-start facilities



PROCESS	WHY?	WHAT IT ENTAILS
Specify AS Tech requirements (ASTR)	Required by the Grid Code	<ul style="list-style-type: none"> • Studies using simulation tools to ensure reliable system • Documenting requirements • Publish requirements on the external site.
AS procurement	Budgeting: to ensure amount is within MYPD	<ul style="list-style-type: none"> • Costing of services • Agree with service provider on costs to be paid
	Contracting: To ensure there is a legal binding to the provision	<ul style="list-style-type: none"> • Determine levels of service from each provider • Compile ASA in conjunction with provider
Certification and testing	To ensure that services agreed can be provided by the agent	<ul style="list-style-type: none"> • Each service needs to be certified to ensure capability • Testing ensures that the provider can do what is required
Performance monitoring	<ul style="list-style-type: none"> • To ensure that the services are performing consistently • For payment purpose 	<ul style="list-style-type: none"> • Weekly performance reports • Monthly performance report • Regular interactions with agents to monitor performance
Payments	Payments as agreed in the ASA/PPA	<ul style="list-style-type: none"> • Derive payments from the monthly performance • Explain deviances • Compile reports



Ancillary Services Technical Requirements (ASTR)

- The first step in securing ancillary services for the year ahead is to specify the technical requirements of the services to be procured (ASTR)”
- this document is published annually on the Eskom website. ([Ancillary Services - Technical Requirements – Eskom](#))


RESERVES REQUIREMENTS

Reserve	Season	Period	2022/23 MW	2023/24 MW	2024/25 MW	2025/26 MW	2026/27 MW
Instantaneous	Summer	Peak	650	650	650	650	650
		Off peak	850	850	850	850	850
	Winter	Peak	650	650	650	650	650
		Off peak	850	850	850	850	850
Regulating	Summer	Peak	530	545	560	575	600
		Off peak	530	545	560	575	600
	Winter	Peak	530	545	560	575	600
		Off peak	530	545	560	575	600
Ten minute	Summer	Peak	1020	1005	990	975	950
		Off peak	820	805	790	775	750
	Winter	Peak	1020	1005	990	975	950
		Off peak	820	805	790	775	750
Operating	Summer/ Winter	Peak/ Offpeak	2200	2200	2200	2200	2200
Emergency			1400	1300	1200	1100	1000
Supplemental			200	300	400	500	600
Total			3800	3800	3800	3800	3800

OTHER SERVICES IN THE ASTR

- The other services stipulated in the ASTR include;
 - Voltage Control
 - Black-start
 - Islanding
 - Constrained generation

- The aggressive plans on reduction of greenhouse gases will have a **major impact** on the day to day running of the integrated power system
- The impact will be seen mainly on **ancillary services** and will include issues such as:
 - transient stability,
 - curtailment of VRE
 - system strength and
 - Flexibility
- In a system with very high RE penetration the system will need units that provide;
 - Faster load ramps**
 - Reliable mingen**
 - More frequent start-ups and shutdowns**
- The AS team has already **initiated exploratory studies** to add the following as new ancillary services
 - fast frequency reserves,
 - self-start capability and
 - Inertia




CURRENT PROVIDERS

- Currently, most of the services are procured from Eskom Generation
- The SO also has a robust Demand Response Program that provides some of the much needed Instantaneous and Supplemental Reserves

FUTURE PROVIDERS

- The SO is actively involved in stipulating services required from IPP programs such as
 - The RMIPPP,
 - The BW6 REIPPP,
 - The Energy Storage Program.
 - The Eskom BESS program
- The SO is looking forward to discussions with other possible providers
- The envisaged Market Operator program will also greatly impact the future of Ancillary Services



Questions?


A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows a solar panel array in front of industrial chimneys. The middle frame shows a large industrial facility with several tall chimneys and a body of water. The bottom frame shows a helicopter lifting a worker in a basket to a high-voltage power line tower.

Summary of the Transmission Refurbishment Plans FY2023 – FY2032

Calvin Govindasamy
Chief Engineer: Asset Investment Planning


- The Asset Management Section is focused on the existing network assets (or the installed base of assets), and to sustain that existing network infrastructure at desired performance levels.
- This is done by removing risks from the network through the replacement of poor condition assets, with consideration of network constraints.
- Asset Management is further responsible for the development of the Refurbishment Plan by identifying refurbishment requirements in terms of capital investments that would ensure that the network conforms to the required reliability and statutory standards.
- The purpose of the presentation is to give an overview of the status of the existing network assets and the planned investments to address replacement of the required equipment.

Substation Asset Condition Assessment: (Main Asset Classes per condition category)



National View

Overhead Lines Asset Condition Assessment: (Main Asset Classes per condition category)




National View

Assets replaced and planned for replacement

Assets Replaced

■ PAST 6-10 Years ■ PAST 1-5 Years




CATEGORY	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	Grand Total
CAPACITOR	1	3	1	5	2		4	6	2	4	28
CIRCUIT BREAKER	26	102	81	86	43	37	98	83	77	174	807
CURRENT TRANSFORMER	99	325	351	142	292	165	336	462	367	511	3,050
DC & STANDBY	62	183	40	14	11	13	8	45	8	5	389
ISOLATORS	90	302	269	150	165	79	268	464	263	642	2,692
PROTECTION	29	118	100	43	80	55	101	161	76	182	945
REACTOR						2	3	7	2	2	16
SURGE ARRESTER	45	201	192	74	173	163	243	334	242	549	2,216
TRANSFORMER	5	2	5		4	4	11	17	13	20	81
VOLTAGE TRANSFORMER	45	118	45	41	115	51	147	198	135	291	1,186
Grand Total	402	1,354	1,084	555	885	569	1,219	1,777	1,185	2,380	11,410


CATEGORY	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	Grand Total
CIRCUIT BREAKER	53	55	55	41	29	41	48	37	40	57	456
CURRENT TRANSFORMER	115	105	195	191	141	231	225	236	202	216	1,857
DC & STANDBY	33	70	29	62	22	19	41	5	5	24	310
ISOLATORS	59	22	35	40	24	31	34	43	57	94	439
PROTECTION	29	20	38	36	31	51	26	37	40	42	350
REACTOR	7	6	21	6	3	1	2	1	2	1	50
SURGE ARRESTER	63	125	192	276	112	122	190	200	134	158	1,572
TRANSFORMER	6	11	13	15	9	13	8	4	4	4	87
VOLTAGE TRANSFORMER	37	47	55	44	39	76	81	135	59	100	673
Grand Total	402	461	633	711	410	585	655	698	543	696	5,794

Assets Planned for Replacement


■ 1-5 Years ■ 6-10 Years



Age Profile: Planned vs Not Planned Replacement



Age Profile: Condition Category



Some of the major focus areas of the Refurbishment Plan are:

1. Operational Risks:

• HV Plant Assets:

- High-Risk Transformers and Reactors are addressed in a phased approach based on network risk.
- Insulation flashover mitigation by re-insulation or surface coating at highly polluted areas
- Reducing network risk due to problematic instrument transformers and surge arrestors that have degraded and reached end-of-life. These are addressed as targeted replacements.
- Circuit Breakers: Application requiring technological advancements and improved functionality

• Protection Schemes:

- Protection schemes are being addressed as a priority focus area and will require an extended replacement programme.
- Certain schemes need to be replaced due to obsolescence and the unavailability of spares
- Application requiring technological advancements and improved functionality

• Fibre:

- Fibre Wrap (e.g. Adlash) installed on some line earth-wires have exceeded their expected lifespan and are now impacting on the line performance. These need to be replaced with Optical Ground Wire (OPGW) which generally is very costly and outage dependent.

- **Powerline Assets:**

- Foundations: Several line foundation designs (built prior to 2004) allowed for bare steel to be in direct contact with the soil, which results in varied levels of degradation based on soil type and weather.
- Insulation and Hardware: Spacer dampers exhibit a lower level of reliability due to the accelerated wear and tear on the conductor.
- Line Insulation is the least reliable of the line components, being under-insulated brought about by changes in design standards, thus forming the bulk of the line asset replacements.

2. **Statutory Risks:**


- **Compliance Requirements:**

- Fault-level exceedances related to equipment ratings
- Environmental legislation in terms of Asbestos and PCB phase-out.
- Adequacy of Oil Containment

- **Infrastructure Security:**

- Addressing statutory fencing requirements for safety, operating and proximity to High Voltage
- Security upgrades to address breaches and theft


Major Refurbishment Projects: FY2023 – FY2032




Capital projects allocation within the Refurbishment Plan



Capital Projects Allocation FY23-32



- Transmission has an adequate planning process to determine asset replacement requirements, which is aligned to Asset Management principles.
- The current portfolio of projects in the refurbishment plan, considers the risks to the network and embodies the requirements and stipulations of the Grid Code.
- The 10-year refurbishment plan is based on actual asset condition assessments, asset criticality, network risks and the undergone a robust prioritisation process.
- The plan is further flexible enough to accommodate emerging operational risks and current requirements in addition to the planned asset replacement program.
- In conclusion, the major refurbishment projects as displayed, are an indication that the refurbishment plan addresses requirements across the country.




Questions?



Transmission Development Plan (TDP) 2023 – 2032 Public Forum




A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows solar panels, the middle frame shows a power plant with cooling towers, and the bottom frame shows a worker on a power line tower.

TDP 2022

Provincial Development Plans

Compiled by: Grid Planning Chief Engineers

Presented by: Caroleen Naidoo / Thokozani Bengani


A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows solar panels, the middle frame shows a power plant with cooling towers, and the bottom frame shows a worker on a power line tower. The background of the slide is white with a blue diagonal stripe in the top left corner.

Transmission Development Plans: Northern Grids


(Mpumalanga, Gauteng, North West, Limpopo and KwaZulu - Natal)

Presented by: Caroleen Naidoo

Northern Region Provincial Demand & Generation Forecast




Conventional generation forecast in MP




Provincial RE generation mix in 2032


Mpumalanga



Limpopo




North West




■ PV ■ Battery Storage ■ Wind

Mpumalanga





Mpumalanga province profile

Load of ~ 4 GW




Generation capacity of ~28 GW



<ul style="list-style-type: none"> ● Existing Substation ● Planned Substation ★ Towns 	<ul style="list-style-type: none"> --- Planned Line — Existing Line 	<p>Voltage (kV)</p>	<p>DATE: 2022/10/04</p> <p>VERSION: 1</p> <p>SCALE: 1:2 600 000</p> <p>DATUM: WGS 84</p> <p>PROJECTION: NO PROJECTION</p> <p>UNIT: DEGREE</p>	<p>Disclaimer: This map has been compiled by Eskom Transmission. Every effort has been made to ensure this map is free of errors, but there is no warrant that the map is either spatially or temporally accurate or fit for a particular use.</p> <p>Note: Data in this map has been simplified for the ease of viewing. The location of features has been misplaced. Do not use this map for any measurements or calculations.</p>
--	---	---------------------	---	--

Mpumalanga Load Forecast




Key Growth Drivers
 Residential
 Commercial
 Tourism
 Mining
 Industrial development

	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Middelburg	638	641	644	663	863	877	883	896	901	941
Lowveld	944	970	1042	1052	1076	1154	1164	1174	1186	1253
Witbank	1237	1254	1264	1274	1096	1104	1112	1129	1145	1162
Highveld South	2114	2254	2265	2276	2287	2293	2150	2153	2158	2157
Provincial Peak	3945	4095	4181	4221	4268	4362	4269	4302	4334	4439
2032 Peak	4439	4439	4439	4439	4439	4439	4439	4439	4439	4439


* Compound Annual Growth Rate

RE Generation Forecast in MP



	2024	2025	2026	2027	2029
Wind	200	800	700	1300	400
PV		254			
Battery Storage			239.5		

Generation developments in Mpumalanga



Prairie
 - 3rd 500 MVA 275/132 kV TRFR

Gumeni
 - 2nd 500 MVA 400/132 kV TRFR

Hendrina
 - 1st 500 MVA 400/132 kV TRFR

Camden B
 - 400 kV LILO
 - 4 x 500 MVA 400/132 kV TRFRs

Majuba
 - 2 x 500 MVA 400/132 kV TRFRs
 - 2 x 315 MVA 400/88 kV TRFR upgrades

Kusile-Lulamisa 400 kV Line
 (In Execution)


Amafutha Switching Station (OCGTs)

Alpha
 - 2 x 500 MVA 400/132 kV TRFRs

2023 - 2027

2028 - 2032

Developments plans for Mpumalanga



Marathon 400 kV Integration

- Gumeni-Marathon line
- 500 MVA 400/132 kV TRFR


Ermelo-Richards Bay Freight Rail Strengthening: Madlanzini Substation

Required to improve security of supply and to increase tonnage capacity

2023 - 2027

2028 - 2032

Development plans for Mpumalanga



Emkhiweni integration

Required to de-load Vulcan and Rockdale unfirm transformations


Amafutha 132 kV Switching Station

Will aid the transition of the load shift to Wonderkrag and will thereafter integrate OCGTs into Sol.

Wonderkrag integration

Required to address the unfirm transformation and fault level exceedance


Gauteng



Gauteng Province Profile

Load


Grid peak demand ~9 845 MW : 24th July '19



Generation

Kelvin Power Station (in Johannesburg) and Rooiwal Power Station (in Tshwane) are some of the Independent Power Producers (IPP's) that lie within the defined Gauteng grid area. There is also potential Biomass IPP's in the region.


The primary sources of power are Cahora Bassa, Lethabo, Matla, Kendal, Duvha, Grootvlei and Matimba power stations.



Load Forecast (2023 – 2032)



Development plans for Johannesburg East and South regions



Mesong Substation

Sisimuka Substation

Brenner 88kV Shunt Capacitors


Jupiter B Integration

Lesokwana Substation

2023 - 2027

2028 - 2032

Development plans for the Tshwane area



Tshwane Phase 2

- Diphororo 400/275kV transformation
- Pelly-Diphororo – Kwagga 275kV line


Diphororo S/S Integration (PTA North)

Wildebees S/S Integration (PTA East, Mamelodi)

2023 - 2027

2028 - 2032

Development plans for the Johannesburg North region



Kusile-Lulamisa 400kV line

Apollo-Lepini 275kV line

Sesiu S/S


Kyalami S/S

Donatello S/S

2023 - 2027

2028 - 2032

Development plans for the West Rand & Vaal area



Hera – Westgate
400 kV Line

Pluto-Westgate
400kV line

Quattro S/S
Integration


Etna 3rd TRFR

Etna-Glockner
2x275kV lines

2023 - 2027

2028 - 2032


North West



North West Province Profile


Load

2021 Peak: 3279 MW




Generation

- There are no power stations located in the North West province. The province is supplied from power stations in Limpopo and Mpumalanga provinces.
- Current installed Renewable Energy is from PV IPPs with an output of 224.9MW




North West Province Load Forecast (2023 – 2032)



Growth Drivers in the Province: Mining, Manufacturing & Agriculture


Developments plans for Carletonville CLN




2023 - 2027

2028 - 2032

Development plans for the Rustenburg CLN



Limpopo




Limpopo Province Profile

Load

- Peak load of 3357 MW in 2020
- Peak load was 3106 MW in 2021


Economic Sectors




- Agriculture
- Mining
- Manufacturing
- Electricity
- Construction
- Trade
- Transport
- Finance
- Community services

Generation

Type	Name	Output
Coal Base	Matimba	3325 MW
Load	Medupi (excl. unit 4)	2382 MW
Renewables	Witkop PV	30 MW
	Soutpan PV	28 MW
	Villa Nora PV	60 MW
	Total Installed Generation	6490 MW



**Limpopo Province
Load Forecast (2023 – 2032)**



Load Drivers

Lephalale Load Growth Drivers:

- Electrification
- Commercial and light industrial load growth
- Platinum and Coal Mining

Polokwane Load Growth Drivers:


- Electrification
- Agriculture
- Diamond and Coal Mining

Phalaborwa Load Growth Drivers:


- Electrification
- Agriculture
- Chrome Mining

*Compound Annual Growth Rate

Limpopo 2022




Limpopo 2032




Limpopo Renewable Energy Forecast

Limpopo Province Renewable Energy Forecast (2023 - 2032)



Strengthening associated with generation integration



**Medupi - Witkop
400 kV line**

**Medupi - Ngwedi
1st 765 kV line
(To be energised at
400 kV)**

**Borutho - Silimela
400 kV line**

2023 - 2027

2028 - 2032

DATE: 2022/09/29
VERSION: 1
SCALE: 1:3 000 000
DATUM: WGS 84
PROJECTION: NO PROJECTION
UNITS: DEGREE

Disclaimer: This map has been compiled by ESKOM Transmission. Every effort has been made to ensure this map is free of errors, but there is no warrant that the map is either spatially or temporally accurate or fit for a particular use. Note: Data in this map has been simplified for the ease of viewing. The location of features has been misplaced. Do not use this map for any measurements or calculations.

Strengthening associated with load growth

Nzhelele integration
Establishment of 400 kV network to the North


Limpopo East Corridor Strengthening
Establishment of 400 kV network to the North East

Sekhukhune S/S Integration

Manogeng and Silimela Integration
Establishment of 400 kV network to the South
Integrate Pump Storage

Increase capacity of existing Substations:
- Leseding
- Borutho

Increase capacity of existing Substations:
- Warmbad
- Acornhoek




2023 - 2027

2028 - 2032

DATE: 2022/09/29
VERSION: 1
SCALE: 1:3 000 000
DATUM: WGS 84
PROJECTION: NO PROJECTION
UNIT: DEGREE

Disclaimer: This map is for information purposes only. It is not a legal document. The map is free of errors, but the user is responsible for its use. Note: Data in this map is for information purposes only. Do not use this map for navigation.

KwaZulu-Natal




KwaZulu-Natal Province Profile


Peak Load

- 5904 MW in 2020
- 6070 MW in 2021

Economic Sectors



- Agriculture
- Electricity
- Transport
- Mining
- Construction
- Finance
- Manufacturing
- Trade
- Community services




Generation


Type		Name	Output
Peaking	Pumped Storage	Drakensberg	1000 MW
		Ingula	1330 MW
IPP	Gas	Avon IPP	680 MW
Total Installed Generation			3010 MW



Kwa Zulu Natal Province Load Forecast (2023 – 2032)



Development plans for Empangeni CLN



Northern KZN Strengthening: Iphiva 400/132 kV Substation

Drivers for demand growth are electrification, tourism and agro processing

Ermelo-Richards Bay Freight Rail Strengthening: Duma & Nzalo Substations

Required to improve security of supply and to increase tonnage capacity.


Mbewu 400 kV Switching Station

Required to increase power transfers to coastal towns and to facilitate integration of gas power plants in Richards Bay

2023 - 2027

2028 - 2032

Development plans for Pinetown CLN




**South Coast Strengthening:
Ariadne-Eros 2nd 400 kV Line**

Required to create capacity to meet demand growth and to improve the security of supply

Inyaninga 400/132 kV Substation

Required to supply the Dube Tradeport as well as commercial and residential developments in eThekweni Metropolitan and KwaDukuza Municipality



Isundu 400 kV Switching Station

Required to provide network redundancy and to increase power transfers to the southern parts of KwaZulu-Natal

Shongweni 400/132 kV Substation


Required to supply commercial and residential developments around Hillcrest, Ntshongweni and Cato Ridge

2023 - 2027

2028 - 2032



Questions?


A decorative graphic on the left side of the slide, consisting of three overlapping circular frames. The top frame shows a close-up of solar panels. The middle frame shows a large industrial facility with several tall, cylindrical cooling towers. The bottom frame shows a worker in a safety harness and hard hat working on a high-voltage power line tower, with a helicopter visible in the background.

Transmission Development Plans: Southern Grids

(Free State, Northern Cape, Eastern Cape and Western Cape)


Presented by: Thokozani Bengani

Provincial Demand & Generation Forecast




Provincial RE generation mix in 2032


Eastern Cape




Free State




Northern Cape



Western Cape



Free State




Free State Province Profile




Load

2021 Peak: 1505 MW




Generation

Type	Name	Output
Base	Coal Lethabo	3558 MW
IPP	Hydro IPPs	4.4 MW
	PV IPPs	199 MW
Total Installed Generation		3761 MW




Free State Province Load Forecast (2023 – 2032)



Growth Drivers in the Province: Industrial, Logistics & Residential Electrification

* Compound Annual Growth Rate

Free State Province Renewable Energy Forecast (2023 - 2032)




Wind

PV

	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Wind						400	400	400	400	400
PV	199	799	999	999	999	1199	1699	2099	2299	2299

Development plans for the Free State Province



Igesi Substation

Mercury 1st 765/400 kV Transformer

Sorata-Tugela 400 kV Line

Everest-Merapi 400 kV Line – **commissioned**

Perseus 2nd 765/400 kV Transformer

	Planned Substation		Planned Line	Voltage (kV)
	Existing Substation		Existing Line	
	Towns			


DATE: 2022/09/27
 VERSION: 1
 SCALE: 1:3 600 000
 DATUM: WGS 84
 PROJECTION: NO PROJECTION
 UNIT S: DEGREE

Disclaimer: This map has been compiled by Eskom Transmission. Every effort has been made to ensure this map is free of errors, but there is no warrant that the map is either spatially or temporally accurate or fit for a particular use.
 Note: Data in this map has been simplified for the ease of viewing. The location of features has been misplaced. Do not use this map for any measurements or calculations.

2023 - 2027

2028 - 2032

Transformer projects to enable RE integration



Scafell Transformer Upgrade

Mercury 3rd 500MVA Transformer

Theseus 3rd 500MVA Transformer

Artemis 2nd 500MVA Transformer

Artemis 3rd 500MVA Transformer

Planned Substation	Planned Line	Voltage (kV)
Existing Substation	Existing Line	
Towns		


DATE: 2022/09/27
 VERSION: 1
 SCALE: 1:3 600 000
 DATUM: WGS 84
 PROJECTION: NO PROJECTION
 UNIT S: DEGREE

Disclaimer: This map has been compiled by ESKOM Transmission. Every effort has been made to ensure this map is free of errors, but there is no warrant that the map is either spatially or temporally accurate or fit for a particular use.
 Note: Data in this map has been simplified for the ease of viewing. The location of features has been misplaced. Do not use this map for any measurements or calculations.

2023 - 2027

2028 - 2032

Northern Cape




Northern Cape Province Profile



Load

2021 Peak Demand: 1178 MW
 Midday Demand: 770 MW




- Agriculture
- Manufacturing
- Commercial
- Mining
- Logistics
- Community Services

Generation

Type		Name	Output
Eskom	Hydro	Gariiep	360 MW
		Van Der Kloof	240 MW
IPP	Hydro	IPPs	10 MW
	CSP	IPPs	600 MW
	Wind	IPPs	965 MW
	PV	IPPs	2303 MW


Total Installed Generation: 4478 MW



CREATED BY:
 SONJA FERREIRA
 COETSES@ESKOM.CO.ZA

● Existing Substation	— Existing Line	Voltage (kV)	DATE: 2022/09/27	Disclaimer: This map has been compiled by Eskom Transmission. Every effort has been made to ensure this map is free of errors, but there is no warrant that the map is either spatially or temporally accurate or fit for a particular use. Note: Data in this map has been simplified for the ease of viewing. The location of features has been misaligned. Do not use this map for any measurements or calculations.
● Planned Substation		86 110 132 220 275 400 533 765	VERSION: 1	
★ Towns			SCALE: 1:5 000 000	
			DATE: WGS 84 PROJECTION: NO PROJECTION UNIT: DEGREE	


Northern Cape Province Load Forecast (2023 – 2032)



Growth Drivers in the Province: Industrial, Logistics & Mining

* Compound Annual Growth Rate

Northern Cape Province Renewable Energy Forecast (2023 - 2032)



Development plans for Namaqualand CLN



Paulputs: LILO
Aries-Kokerboom
400 kV Line


Aggeneis-
Paulputs 400 kV
Line & 400/132 kV
Transformer

Aries-Aggeneis-
Gromis 400 kV
Line

Korana 400/132 kV
Substation

Gromis-Juno 400
kV Line & 400/220
kV Transformer

Aries SVC




<ul style="list-style-type: none"> ● Existing Substation ● Planned Substation ★ Towns 	<ul style="list-style-type: none"> --- Planned Line — Existing Line 	<p>Voltage (kV)</p> <p>88 110 132 220 275 400 533 765</p>	<p>DATE: 2022/09/27</p> <p>VERSION: 1</p> <p>SCALE: 1:5 000 000</p> <p>DATUM: WGS 84</p> <p>PROJECTION: NO PROJECTION</p> <p>UNITS: DEGREE</p>	<p>Disclaimer: This map has been compiled by Eskom Transmission. Every effort has been made to ensure this map is free of errors, but there is no warrant that the map is either spatially or temporally accurate or fit for a particular use.</p> <p>Note: Data in this map has been simplified for the ease of viewing. The location of features has been misplaced. Do not use this map for any measurements or calculations.</p>
--	---	---	--	--

2023 - 2027

2028 - 2032

Development plans for Karoo CLN



- Hydra-Kronos-Aries 400 kV line
- Hydra B 400/132 kV
- Perseus-Gamma-Sterrekus 765 kV Line 2
- Hydra 2nd 765/400 kV Transformer
- Siyoneza 765 kV Strengthening
- Nuweveld-Loxton-Siyoneza Strengthening
- Gamma 1st 765/400 kV Transformer

<ul style="list-style-type: none"> ● Existing Substation ● Planned Substation ★ Towns 	<ul style="list-style-type: none"> --- Planned Line — Existing Line 	<p>Voltage (kV)</p> <table border="0"> <tr> <td style="width: 20px; height: 10px; background-color: black;"></td> <td style="width: 20px; height: 10px; background-color: grey;"></td> <td style="width: 20px; height: 10px; background-color: lightblue;"></td> <td style="width: 20px; height: 10px; background-color: orange;"></td> <td style="width: 20px; height: 10px; background-color: yellow;"></td> <td style="width: 20px; height: 10px; background-color: green;"></td> <td style="width: 20px; height: 10px; background-color: lightgreen;"></td> <td style="width: 20px; height: 10px; background-color: magenta;"></td> </tr> <tr> <td>88</td> <td>110</td> <td>132</td> <td>220</td> <td>275</td> <td>400</td> <td>533</td> <td>765</td> </tr> </table>									88	110	132	220	275	400	533	765
88	110	132	220	275	400	533	765											


DATE: 2022/09/27
 VERSION: 1
 SCALE: 1:5 000 000
 DATUM: WGS 84
 PROJECTION: NO PROJECTION
 UNITS: DEGREE

Disclaimer: This map has been compiled by Eskom Transmission. Every effort has been made to ensure this map is free of errors, but there is no warrant that the map is either spatially or temporally accurate or fit for a particular use.
 Note: Data in this map has been simplified for the ease of viewing. The location of features has been misplaced. Do not use this map for any measurements or calculations.

2023 - 2027

2028 - 2032

Development plans for Kimberley CLN



Ferrum-Mookodi-Mercury 400 kV Line

Umtu Substation

Beta-Boundary-Ferrum 400 kV Line & Boundary 400/132 kV

Mercury-Aries-Juno-Sterrekus 765 kV Line

Ferrum-Upington 400 kV Line

Upington 2nd 400/132 kV Transformer

Aries-Upington 400 kV Line

● Existing Substation	- - - Planned Line	Voltage (kV)
● Planned Substation	— Existing Line	88 110 132 220 275 400 533 765
★ Towns		


DATE: 2022/09/27
 VERSION: 1
 SCALE: 1:5 000 000
 DATUM: WGS 84
 PROJECTION: NO PROJECTION
 UNITS: DEGREE

Disclaimer: This map has been compiled by Eskom Transmission. Every effort has been made to ensure this map is free of errors, but there is no warranty that the map is either spatially or temporally accurate or for a particular use. Note: Data in this map has been simplified for the ease of viewing. The location of features has been misplaced. Do not use this map for any measurements or calculations.

2023 - 2027

2028 - 2032

Transformer projects to enable RE integration



Upington 3rd Transformer

Garona 400/132 kV Transformer

Aggeneis 400/132 kV Transformer

Aries 400/132 kV Transformer

Kronos 2nd 400/132 kV Transformer

Kronos 3rd 400/132 kV Transformer

Hydra Transformer Upgrade

Gamma 2nd 400/132 kV Transformer


Helios 2nd Transformer

Gromis, Nama, Groeipunt 400/132 kV Transformers

2023 - 2027



2028 - 2032

Eastern Cape




Eastern Cape Province Profile

2020 Recorded
Peak 1545 MW




Generation

Type		Name	Output
Peaking	Gas	Port Rex	171 MW
		Dedisa	372 MW
RE IPP	Wind & Solar	ALL	~1782 MW
Total Installed Generation			~2325 MW



Development plans for East London CLN



Dorper 400/132 kV Substation

Poseidon North 400/132 kV Substation

Pembroke 400 kV Integration

Poseidon-Pembroke 400 kV Line


● Existing Substation	- - - Planned Line	Voltage (kV)
● Planned Substation	— Existing Line	
★ Towns		

DATE:	2022/10/12	Disclaimer: This map has been compiled by Eskom Transmission. Every effort has been made to ensure this map is free of errors, but there is no warranty that the map is either spatially or temporally accurate or fit for a particular use. Note: Data in this map has been simplified for the ease of viewing. The location of features has been misplaced. Do not use this map for any measurements or calculations.
VERSION:	1	
SCALE:	1:4 000 000	
DATUM:	WGS 84	
PROJECTION:	NO PROJECTION	
UNITS:	DEGREE	

2023 - 2027

2028 - 2032

Development plans for Port Elizabeth CLN



EC-KZN 765 kV Lines

Poseidon South Integration

Gamma-Grassridge 765 kV Lines

Grahamstown Integration

Coega Gas Integration

Hlaziya Integration


● Existing Substation	- - - Planned Line	Voltage (kV)
● Planned Substation	— Existing Line	
★ Towns		

DATE:	2022/10/12	Disclaimer: This map has been compiled by ESKOM Transmission. Every effort has been made to ensure this map is free of errors, but there is no warranty that the map is either spatially or temporally accurate or fit for a particular use.
VERSION:	1	
SCALE:	1:4 000 000	Note: Data in this map has been simplified for the ease of viewing. The location of features has been misplaced. Do not use this map for any measurements or calculations.
DATUM:	WGS 84	
PROJECTION:	NO PROJECTION	
UNITS:	DEGREE	

2023 - 2027

2028 - 2032

Transformer projects to enable RE integration



Delphi 500 MVA Transformer

Grassridge 4th 500 MVA Transformer

Dedisa 3rd & 4th 500 MVA Transformers

● Existing Substation	- - - Planned Line	Voltage (kV) 88 110 132 220 275 400 533 765
● Planned Substation	— Existing Line	
★ Towns		


DATE: 2022/10/12
 VERSION: 1
 SCALE: 1:4 000 000
 DATUM: WGS 84
 PROJECTION: NO PROJECTION
 UNITS: DEGREE

Disclaimer: This map has been compiled by Eskom Transmission. Every effort has been made to ensure this map is free of errors, but there is no warranty that the map is either spatially or temporally accurate or fit for a particular use.
 Note: Data in this map has been simplified for the ease of viewing. The location of features has been misplaced. Do not use this map for any measurements or calculations.

2023 - 2027

2028 - 2032

Western Cape



Western Cape Province Profile

Transmission Network



400 kV: ~2 800 km

765 kV: ~550 km



14 Substations

50 Transformers

16 300 MVA

Load



Peak load: ~ 4 000 MW

Generation




Installed: 6 024 MW

CLNs

Outeniqua

Peninsula

West Coast




Eskom Power Stations in the Western Cape

Eskom Power Stations		
Acacia	19	171 MW
Ankerlig	21	1 327 MW
Gourikwa	22	740 MW
Koeberg	5	1 830 MW
Sere	23	100 MW
Palmiet	18	400 MW
Total		4 568 MW




IPPs in the Western Cape

IPPs (up to RMIPPPP)	
PV	134 MW
Wind	874 MW
Gas	320 MW
Hybrid	128 MW
Total	1 456 MW



Western Cape Province Load Forecast (2023 – 2032)



* Compound Annual Growth Rate

Development plans for Peninsula CLN


Ankerlig – Sterrekus
1st & 2nd 400 kV lines
– **commissioned**

Relocate Koeberg
offsite supply to
Ankerlig

Operate Koeberg –
Acacia 2nd line at
400 kV

Erica Substation

Pinotage Substation
– **commissioned**




Substations		Lines	
Existing	Planned	220 kV	275 kV
Existing	Planned	400 kV	533 kV
Existing	Planned	765 kV	765 kV
Existing	Planned	Series capacitor	

2023 - 2027

2028 - 2032

Development plans for Outeniqua and West Coast CLNs



Kappa 2nd 765/400 kV Transformer

Bokkom Substation (Phase 1)

Asteria Substation


Agulhas Substation

Narina Substation

2023 - 2027

2028 - 2032

Major developments to enable RE integration



Cape Corridor Phase 5 and 6 (new 765 kV corridor)

Cape Corridor Phase 4 (2nd 765 kV line)

Aurora – Juno 2nd 400 kV line

Galenia Substation (IPP Self-build)

Komsberg Substation – commissioned

Droërivier – Narina – Gourikwa 400 kV line

Kappa ext. 400/132 kV – commissioned


Koring Substation (IPP Self-build)

Asteria Substation

Agulhas Substation

2023 - 2027

2028 - 2032



Transformer projects to enable RE integration


**Komsberg
3rd 500 MVA**

**Kappa
2nd 500 MVA**

**Droerivier
1st 500 MVA**

**Galenia
2nd 500 MVA**

**Koring
2nd 500 MVA**



2023 - 2027

2028 - 2032



Questions?



Transmission Development Plan 2023 – 2032

Summary and Capex Analysis

Leslie Naidoo
Senior Manager: Transmission Grid Planning


Current situation

- The IRP 2019 that was gazetted in November 2019, proposes ~ 30 **GW** of new generation capacity to be connected to the system by **2030**. When considering the Eskom 2035 Corporate strategy, applications processed via the DMRE procurement programmes, non-DMRE applications and engagements with RE associations, ~ 53GW of new generation capacity will be required by 2032. Failure to deliver will lead to an increased risk to the security of electricity supply for the country.
- Current network reliability constraints (N-1) as well as meeting the anticipated demand growth also requires significant new network infrastructure.
- This will require an **acceleration of investments** in Transmission infrastructure by development of new corridors and substations, and strengthening at existing substations over the period 2023 – 2032 to address both the new generation capacity, as well as the network strengthening requirements across the country for **security of supply**.




Problem statement

- The grid strengthening required to accommodate this aggressive renewable integration, as well as ensuring the sustainability of the network requires **significant investments**.
- Timelines to implement Transmission Infrastructure take ~ **8 – 10 years** to build due to **servitude challenges**.
- The **resource capacity** in the country across the EPCM value chain is limited.
- The **capital requirements** to achieve the TDP is substantial and is limited by the Eskom's balance sheet.



What is the challenge?


We are facing coal decommissioning – 9,5GW by 2030 and continues beyond




IRP 2019 capacity requirements

	IRP 2019					Total	Delta	
	Coal	Storage	PV	Wind	Gas			
2020	1433		114	300		1847	0	
2021	1433		300	818		2551	0	
2022	711	513	1400	1600		4224	3113	9.7GW
2023	750		1000	1600		3350	2850	
2024				1600	1000	2600	2100	
2025			1000	1600		2600	1730	
2026				1600		1600	-3150	17GW
2027	750			1600	2000	4350	550	
2028			1000	1600		2600	-1800	
2029		1575	1000	1600		4175	-1275	
2030			1000	1600		2600	0	
Totals:	5077	2088	6814	15518	3000	32497	4118	

1.87 GW					11.66 GW				
2022	711		400		711	513	1400	1600	
2023	500				750			1000	1600
2024	500							1600	1000
2025			670	200			1000	1600	



Not only brought forward but also compressed





Renewables brought forward from 2018 IRP to 2019 IRP by 9,8GW



What is the challenge? cont.

Northern Cape Supply Area with most efficient solar resource taking into account DFFE and CSIR restriction areas has no connection capacity after BW5 / RMIPPP

Solar sites(yellow) & lowest cost(red)



Significant transmission development is required in the northern, central and southern corridors




Transmission network infrastructure augmentation in areas with Renewable Energy resources is critical for the Country to maximise on the lowest cost energy

What does this mean for the Transmission network?


Significant transmission development is required in the northern, central and southern corridors

LOAD
22% 78%




Lower load in the South remains

GENERATION
52% 48%




Generation increase in the South



Transmission development plan: 2023 - 2032

LEGEND

- Projects in execution
- Projects in development
- Projects in concept



Northern Cape 765kV Corridor

West Coast Strengthening

Central Cape 765kV Corridor

Peninsula / Mitchells Plain

Eastern Cape 765kV Corridor

E-Cape - KZN 765kV Corridor

East London Strengthening

Empangeni Strengthening

Pinetown Strengthening

KZN South Strengthening

Bloemfontein Strengthening

Port Elizabeth Strengthening

Northern Cape Strengthening

Upington Phase 2 Substation

NW / Kimberley Strengthening

Jhb East Strengthening

Jhb South Strengthening

Medupi Phase 2 Integration

Nzhelele Integration

Lowveld Strengthening

Kusile Integration

Highveld South Integration

Empangeni Strengthening

Pinetown Strengthening

KZN South Strengthening

Bloemfontein Strengthening

Port Elizabeth Strengthening

Northern Cape Strengthening

ORANJEMOND

AGGENEIS

GROMIS

NAMA

HELIOS

JUNO

STERREKOP

Upington Phase 2 Substation

PAULPUTS

KORONA

ARIES

HELIOS

JUNO

AURORA

KAPPA

BACCHUS

Hotazel

FERRUM

OLIEN

BOUNDARY

HYDRUS

GAMMA

DROERIVIER

KORNSBERG

PROTEUS

Mahikeng

MERCURY

PERSEUS BETA

HARVARD

ROODEKUIL

RUIGTEVALLEI

POSEIDON

GRASSRIDGE

GRASSRIDGE

HERMES

MAJUBA

LEANDER THESEUS

INGULA

DRAKENSBURG

VENUS

DELPHI

NEPTUNE

NEPTUNE

Highveld South Integration

MAJUBA

INGULA

DRAKENSBURG

VENUS

DELPHI

NEPTUNE

NEPTUNE

NEPTUNE

Nzhelele Integration

Lowveld Strengthening

Kusile Integration

Highveld South Integration

Empangeni Strengthening

Pinetown Strengthening

KZN South Strengthening

Bloemfontein Strengthening

Port Elizabeth Strengthening

Medupi Phase 2 Integration

MEDUPI

MATIMBA

MEDUPI MASA

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

Nzhelele Integration

Lowveld Strengthening

Kusile Integration

Highveld South Integration

Empangeni Strengthening

Pinetown Strengthening

KZN South Strengthening

Bloemfontein Strengthening

Port Elizabeth Strengthening

Jhb South Strengthening

Jhb East Strengthening

NW / Kimberley Strengthening

Upington Phase 2 Substation

Northern Cape Strengthening

ORANJEMOND

AGGENEIS

GROMIS

NAMA

HELIOS

JUNO

STERREKOP

Upington Phase 2 Substation

PAULPUTS

KORONA

ARIES

HELIOS

JUNO

AURORA

KAPPA

BACCHUS

Hotazel

FERRUM

OLIEN

BOUNDARY

HYDRUS

GAMMA

DROERIVIER

KORNSBERG

PROTEUS

Mahikeng

MERCURY

PERSEUS BETA

HARVARD

ROODEKUIL

RUIGTEVALLEI

POSEIDON

GRASSRIDGE

GRASSRIDGE

HERMES

MAJUBA

LEANDER THESEUS

INGULA

DRAKENSBURG

VENUS

DELPHI

NEPTUNE

NEPTUNE

Highveld South Integration

MAJUBA

INGULA

DRAKENSBURG

VENUS

DELPHI

NEPTUNE

NEPTUNE

NEPTUNE

Medupi Phase 2 Integration

MEDUPI

MATIMBA

MEDUPI MASA

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

Nzhelele Integration

Lowveld Strengthening

Kusile Integration

Highveld South Integration

Empangeni Strengthening

Pinetown Strengthening

KZN South Strengthening

Bloemfontein Strengthening

Port Elizabeth Strengthening

Jhb South Strengthening

Jhb East Strengthening

NW / Kimberley Strengthening

Upington Phase 2 Substation

Northern Cape Strengthening

ORANJEMOND

AGGENEIS

GROMIS

NAMA

HELIOS

JUNO

STERREKOP

Upington Phase 2 Substation

PAULPUTS

KORONA

ARIES

HELIOS

JUNO

AURORA

KAPPA

BACCHUS

Hotazel

FERRUM

OLIEN

BOUNDARY

HYDRUS

GAMMA

DROERIVIER

KORNSBERG

PROTEUS

Mahikeng

MERCURY

PERSEUS BETA

HARVARD

ROODEKUIL

RUIGTEVALLEI

POSEIDON

GRASSRIDGE

GRASSRIDGE

HERMES

MAJUBA

LEANDER THESEUS

INGULA

DRAKENSBURG

VENUS

DELPHI

NEPTUNE

NEPTUNE

Highveld South Integration

MAJUBA

INGULA

DRAKENSBURG

VENUS

DELPHI

NEPTUNE

NEPTUNE

NEPTUNE

Medupi Phase 2 Integration

MEDUPI

MATIMBA

MEDUPI MASA

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

MEDUPI

Nzhelele Integration

Lowveld Strengthening

Kusile Integration


Highveld South Integration

Empangeni

Accelerating grid capacity for RE: North and South scenario by introduction of additional transformations ~ 16.6 GW

North Scenario: (12.1 GW)

- 23 transformations projects at various sites



South Scenario: (4.5 GW)

- 13 transformations projects at various sites

Summary of Transmission infrastructure requirements over the TDP 2022 period 2023 - 2032

Transmission Assets Nationally	New Assets expected	New Assets expected	Total New Assets:
	2023 - 2027	2028 - 2032	2023 - 2032
Power lines (km)			
765 kV	200	6128	6328
400 kV	2679	5019	7698
275 kV	14	178	192
Total length (km)	2893	11325	14218
Transformers			
Number of units	60	110	170
Total capacity (MVA)	26970	78 895	105865
Capacitors			
Number of units	11	29	40
Total capacity (MVar)	560	2 140	2700
Reactors			
Number of units	6	46	52
Total capacity (MVar)	600	14 113	14713

What the network requires to meet the generation and demand growth for the Country:


Assumptions: Capex, servitudes, resource capacity and capability across the EPCM value chain are resolved.



**Our focus is on the next 5 years
While we resolve the challenges in the later years**

Summary of Transmission Capex Plan (R Million) FY 2023 – 2027

Transmission Capex: Categories (Rmil)	Total FY 23 - 27
Capacity Expansion	47 761
Refurbishment	9 726
EIA & Servitudes	3 029
Telecommunications	3 116
Production Equipment	2 102
Strategic Spares	6 434
	72 168



- Network capacity constraints especially in the Northern, Western and Eastern Cape regions require significant network augmentations in terms of 765kV corridors across many provinces
- Capex requirements to fund the new network infrastructure and refurbishment plans will impact Eskom's balance sheet
- Deferrals over the years place huge pressure on the Transmission build programme into "back loading" as well as on the sustainability of supplier and construction industry
- The major risks in implementing the TDP 2022 are:
 - Time taken to acquire servitudes
 - Constrained resource capacity in the country across the engineering, procurement, and construction value chain to execute the plan
 - Capex requirements especially in the latter 5 years of the plan



Questions?



Transmission Development Plan (TDP) 2023 – 2032 Public Forum





TDP 2022

Delivery Interventions

Prince Moyo


General Manager: Asset Management

1. Background
2. TDP Delivery SteerCo
3. TDP 2022 Physicals
4. Contracts Status
5. Future Focus


1. Background

TDP 2021

~ 8406 km of line:



~ 119 transformers ~ 58 GVA:




F22-26 cf F17-21: **73%** increase in line km, **94%** increase in transformers
F27-31: **124%** increase in line km, **140%** increase in transformers


1. Background

TDP 2022

~ 14218 km of line:



~ 170 transformers ~ 106 GVA:




Compared to the previous 5yrs: **98%** increase in line km, **328%** in transformers
Following 5yrs (FY28–FY32): **290%** increase in line km, **83%** in transformers

Background:


- TDP Delivery SteerCo established in December 2020
- It is a sub-committee of Transmission Board
- PMO in place and senior managers formally appointed as Project Leader and Programme Manager
- SteerCo has set out priority areas and recorded some achievements; outlined in later slides
- Engagements have been conducted with industry (bilaterally and in open workshops), development agencies (IDC) and government (DTIC, DFFE, DPWI)
- Project plan indicates that the last major step change interventions will be achieved by December 2023

TDP Delivery Streams




2. TDP Delivery SteerCo

TDP Delivery Priority Initiatives




TDP Delivery Streams - Achievements




3. TDP 2022 Physicals


Transformer Requirements (MVA) TDP2021 vs TDP2022




Transformer Requirements (Units) TDP2021 vs TDP2022




Transmission Line Length Requirements (km) for the TDP TDP2021 vs TDP2022






*info not available yet for TDP2022

TX COMPOSITE INSULATORS



*info not available yet for TDP2022

Active vs Expired Contracts




- Overall Contract Status - Tx Number of Active Contracts
- Overall Contract Status - Tx Closed / expired Contracts

Open Contracts = 80

Expired Contracts = 04

TDP Delivery Streams – Future Focus





Questions?



TDP 2022

Projects in Execution

Naresh Singh

General Manager: Transmission Projects Delivery

Partnership is required in the execution of the TDP

Joint commitment is required in delivering on fundamental building block of this country, entrusted to us by Government and people of South Africa

Previous discrepancies between the TDP and the execution plan due to various reasons

However, the TDP and execution plans are getting closer aligned

- Change in generation mix requires more Tx connections
- New/Renewable energy is here to stay
- Significant increase capital allocation
- Changes in the regulatory and governance environment

The biggest challenge is to:

- Deliver what the country needs
- In a manner that is cost and time efficient
- That lasts the duration for which the assets are meant to last
- In a safe, environmentally and socially responsible way

Project Execution challenges, improvement initiatives and opportunities

Procurement process inefficiencies

- Implemented earlier approval of procurement strategies where applicable
- Implemented Panel contracts to shorten duration to contract award
- Procurement process gap analysis and process improvements ongoing (Reduced National Treasury approvals, single and sole source practices etc.)
- Process improvements to reduce contract termination, liquidation, arbitration/adjudication
- Reduce re-tenders, reduce tender requirements – but suppliers and contractors to read documents, follow requirements, attend clarification sessions
- Cost effective pricing from the market is required
- Reduce tender period extensions from the market

Contracting methodology change required

- Change in primary contracting strategy from multiple packages with free issue to EPC
- Expectations is that this will result in speedier execution at a lower costs, still need to meet developmental objectives
- 4 x EPC contracts to the market by March 2023, 2 x issued to the market in October 2022
- Owners Engineer and EPC panel implementation to commence

Project Execution challenges, improvement initiatives and opportunities



Bespoke Engineering designs

- Challenging current engineering practices with a view of simplifying procurement and manufacturing whilst reducing capital cost
- EPC approach will also help uncover overdesign which is costly and complex to implement

Insufficient line contractor capacity

- Line contractor incubation program - RFI issued to the market, evaluations nearing completion, target 4 contractors on incubation model

Limited number of steel suppliers

- Accredited additional steel suppliers - RFI issued to the market, next steps to evaluate submissions and desktop accreditation


Project community instability

- Stability guideline implemented, conducted whilst project is in development phase, include as tender returnable
- Security Threat Assessment is conducted, Security Advisors assigned
- Security contract implementation ongoing

- Sense of urgency is required
- Cost prudence and returning transmission capital costs to globally competitive costs
- Efficient project execution after contract award – done correctly the first time, executed as planned
- Quality workmanship that will last generations
- Safe execution - we can never let our guard down
- Compliance to environmental safeguards and social commitments
- Continuous education and pipelining
- Ethical behavior – let us jointly return the business to the highest ethical standards



Questions?



Thank you