

Transmission

Development Plan (TDP)



elcome



Safety evacuation procedure



NTCSA Transmission Development Plan 2025 to 2034 (TDP 2024)

Date: 30 October 2024



| 08:30 - 09:00 | Join MS Teams Live Event | All | | |
|--|--|--|--|--|
| 09:00 - 09:05 | Opening and welcome | Dudu Hadebe Senior Consultant: Grid Planning | | |
| 09:05 - 09:20 | Keynote address | Segomoco Scheppers Interim Chief Executive Officer: NTCSA | | |
| 09:20 - 09:45 | TDP 2024 Background & Grid Connection Progress | Makoanyane Theku Senior Manager: Customers and Grid Connection | | |
| 09:45 - 10:00 | RE Impacts on System Operations & Implications to Ancillary Services | Paul Davel Chief Engineer: System Operations | | |
| 10:00 - 10:25 | TDP 2024 Assumptions (Demand & Generation) | Jana Breedt / Caswell Ndlhovu Chief Advisor / Engineer: Strategic Grid Planning | | |
| 10:25 - 10:40 | Generation Capacity Analysis and Grid Impacts | Ronald Marais Senior Manager: Strategic Grid Planning | | |
| 10:40 - 11:10 | Tea Break | All | | |
| 10.40 - 11.10 | | | | |
| 11:10 - 12:00 | Provincial Development Plans (Southern & Northern Supply Areas) | Ahmed Hansa / Caroleen Naidoo Chief Engineers: Grid Planning | | |
| | | Ahmed Hansa / Caroleen Naidoo | | |
| 11:10 - 12:00 | Northern Supply Areas) | Ahmed Hansa / Caroleen Naidoo Chief Engineers: Grid Planning Atha Scott | | |
| 11:10 - 12:00 12:00 - 12:15 | Northern Supply Areas) Summary of Grid Assets Refurbishment Plans | Ahmed Hansa / Caroleen Naidoo Chief Engineers: Grid Planning Atha Scott Senior Manager: Asset Investment Planning Leslie Naidoo | | |
| 11:10 - 12:00 12:00 - 12:15 12:15 - 12:30 | Northern Supply Areas) Summary of Grid Assets Refurbishment Plans TDP 2024 Summary | Ahmed Hansa / Caroleen Naidoo Chief Engineers: Grid Planning Atha Scott Senior Manager: Asset Investment Planning Leslie Naidoo Senior Manager: Grid Planning | | |
| 11:10 - 12:00 12:00 - 12:15 12:15 - 12:30 12:30 - 13:30 | Northern Supply Areas) Summary of Grid Assets Refurbishment Plans TDP 2024 Summary <i>Lunch Break</i> | Ahmed Hansa / Caroleen Naidoo Chief Engineers: Grid Planning Atha Scott Senior Manager: Asset Investment Planning Leslie Naidoo Senior Manager: Grid Planning All Makgwanya Maringa | | |



Keynote Address:

Segomoco Scheppers Interim Chief Executive Officer NTCSA





TDP 2024 Background & Grid Connections Progress:

Makoanyane Theku

Senior Manager: Customers & Grid Connection



Background to the TDP 2024




- The TDP emanates from the Grid Code, which states that "The *NTC* shall annually publish a minimum five-year-ahead *TS* development plan by end October, indicating the major capital investments planned *(but not necessarily approved)*."
- The key changes from the last TDP 2022 is associated with the new generation capacity assumptions for the country as proposed in the draft IRP 2023. Apart from the draft IRP 2023, the TDP 2024 also considered:
 - Eskom's revised generation decommissioning strategy,
 - Connection applications processed through the various DMRE procurement programmes,
 - Applications processed from the non-DMRE "private sector" procurement programmes,
 - Information obtained through Renewable Energy (RE) surveys and consultations with RE associations, as well as
 - The impact of large scale RE integration on system stability and security of supply.



- The outcome of the TDP is a list of projects with a high-level scope, cost, and time for the new infrastructure requirements to meet the specific objectives of each project.
- Following the publication of the TDP, each project undergoes a detailed power system analysis study in accordance with the Grid Code, considering alternative options, to determine the most technically and economically viable solution.
- The execution of individual transmission expansion projects follows the project life cycle model (PLCM) and is contingent on business case approvals in accordance with the NTCSA governance approval process.
- On an annual basis, NERSA conducts an audit on the TDP, the assumptions and process followed, and on a selection of approved projects for compliance to the Grid Code.

Background to the TDP (consultative process)





Overview and purpose of the TDP Public Forum




The purpose of the presentation is to:

- Contextualise the planning timelines relating to the demand forecast and generation patterns
- Share information and results relating to the integration of new generation capacity and address the future network requirements
- Share assumptions and results from the Transmission Development Plan 2025 2034 for both the capacity expansion and refurbishment portfolios
- Share information on the initiatives undertaken to implement the TDP, as well as challenges experienced on projects in execution
- More importantly, to solicit comments and inputs to improve on the Transmission Plans



The objectives of the TDP are to attain Grid Code compliance and determine new infrastructure and asset replacement requirements





The Transmission Development Plan has four main objectives

Attain Grid Code compliance by resolving both substation and line violations (N-1)

Determine **new network infrastructure requirements** to sustain and allow for future demand growth


Determine **new network infrastructure requirements** to **integrate new** generation capacity and address system stability requirements



Consider asset replacement requirements to ensure reliability of supply and network optimisation

Planning for the integrated power system





Grid Connections overview – end Sept 2024



Announced preferred bidders for Department of Energy and Electricity Independent Power producers programmes

| Peakers | REIPP BW1 | REIPP BW2 | REIPP BW3&3.5 | REIPP BW4&4B | RMIPPP | REIPP BW5 | REIPP BW6 | BESIPP BW1 |
|------------------------|---------------------------|---------------------------|--|---------------------------|--|---|---|--|
| 2 projects 1135 MW | 28 projects 1434 MW | 19 projects 1070 MW | 18 projects 1628 MW | 26 projects 2205 MW | 11 projects 1998 MW | 25 projects 2583 MW | 6 projects 1000 MW | 5 projects 513 MW |
| All projects connected | All projects connected | All projects connected | 17 projects connected, 1 project in execution | All projects connected | 3 Projects connected, 3 in execution | 25 preferred bidders, of which 11 projects are in execution | 6 Preferred bidders announced, of which 2 projects are in execution | 5 Preferred bidders announced and currently in development |

Total preferred bidders projects announced ~ 13,5 GW from 140 individual projects

95 projects totalling 7522 MW have been commissioned, of which 6387 MW is from RE Sources

17 projects totalling 1797 MW are in execution


Private off-taker projects

585 MW of renewable energy projects have been connected to the grid for private-offtake mechanisms

48 additional renewable energy projects for private-offtake mechanisms, totalling 3.4 GW are currently in execution

Grid connections summary and trends analysis

- In total, more than 8 GW of generation from IPPs has been connected to the grid, with additional 5.2 GW currently in execution.
- NTCSA has committed Capital to enable the grid connection of projects in execution, where required.
- The transmission network capacity in the Western, Eastern, Northern Cape and parts of the North-West supply areas is severely constrained and would require substantial strengthening at local and corridor level to provide additional network capacity to integrate the new generation plants to the system.



Observations

- Rapid increase in the volume of grid connection applications since 2022:
 - Increase in number of applications, connection capacity and plant sizes

National Transmission Compan<u>y South Africa ™</u>

Challenges

- Supply vs sink mismatch for grid connection studies
- Increased connection studies complexity and processing time

Therefore, continued collaboration and timeous sharing of accurate information is essential for efficient and effective management of grid connections.



Apart from the TDP assumptions and provincial plans that we normally share at the public forum, today's presentation also includes:

- 1) The System Operator's experiences with RE connected to the grid and impacts to Ancillary Services
 - Ancillary Services
- 2) Progress on the TDP implementation programme
- 3) Experiences related to projects in execution

I hope you find today's engagements fruitful, and we look forward to your feedback!



Renewable Energy (RE) Impacts on System Operations & Implications to Ancillary Services

Paul Davel Chief Engineer: System Operator





- The role of the System Operator (SO) is to control and operate the system in a way that is safe, reliable and efficient.
- Ultimately, SO is technology neutral in terms of energy sources we just need to ensure that we have tools at our disposal to manage frequency, voltage, network loading, etc. under normal and emergency conditions.
- The operation of networks supplied by conventional generation is well understood, both internationally and locally. The increasing penetration of RE means that different challenges arise that may, or may not, require different tools to satisfy the mandate of the System Operator. Fortunately, there is international experience and best practices that can be applied and modified to suit South African conditions.
- The system is changing rapidly, particularly due to the proliferation of rooftop PV systems these have changed the behaviour of the load in many instances and their installation has rapidly outstripped the installation of contracted installations.
- The proliferation of rooftop PV has helped to suspend load shedding mostly by reducing reliance on emergency resources (OCGTs and pumped-storage) during daylight hours, which means that diesel and dam levels can be maintained. This is a secondary effect – the biggest contributor is the improvement of fossil stations' Energy Availability Factor (EAF).



October 2021

| Current Installed Capacity (MW) | | | |
|---------------------------------|---------|--|--|
| CSP | 500.0 | | |
| PV | 2,212.1 | | |
| Wind (Eskom+IPP) | 3,023.4 | | |
| Total (Incl other REs) | 5,761.0 | | |


October 2024

| Current Installed Capacity (MW) | | |
|---------------------------------|---------|--|
| CSP | 500.0 | |
| PV | 2,287.1 | |
| Wind (Eskom+IPP) | 3,442.6 | |
| Hybrid | 150.0 | |
| Total (Incl other REs) | 6,430.2 | |
| Estimated Rooftop PV* | 6,141.4 | |

- Minimal increase in PV
- Approximately 420 MW additional Wind
- New Hybrid generation
- Total increase of almost 670 MW
- Consistent load shedding during 2022 and 2023, coupled with double digit price increases, have driven the growth in behind-the-meter installations.


Growth of "Rooftop" PV





Impact of rooftop (behind the meter) PV






Identical stages and times of load shedding on both days

Comparison of a cold day with poor PV vs a warmer day with abundant PV

Wind generation characteristics








During the summer months, the wind generation aligns almost perfectly to the high evening peak demand and the low night minimum demand.

However, in winter, when the cold front passes through the Western and Eastern Cape, the wind generation increases significantly.


As the cold front arrives in densely populated Gauteng, the cold weather drives demand for electricity up and at the same time the wind generation reduces significantly due to the low trough behind the front. This double whammy requires 1000's of MW of generation to be dispatched in a short period of time to compensate for the reduced generation and increased demand.




 System reserves to combat generation/load contingencies and forecast errors. These include instantaneous, regulating, ten-minute, supplemental and emergency reserves



- Reactive power and voltage control to maximise system security and reduce network losses.
- Constrained generation to compensate those generators dispatched out of the merit order and suffer financial loss due to lack of related market rules dealing with transmission constraints and units in strategic positions.
- System restoration services to expedite system restoration resulting from regional and system-wide interruption of supply. These include Black-start, Islanding and in future self-start facilities







Changes in the Ancillary Services space







TDP 2024 Assumptions (Demand & Generation)

Jana Breedt / Caswell Ndlhovu


Chief Advisor / Engineer: Strategic Grid Planning



The TDP follows a rigorous and iterative development process, primarily driven by electricity demand and supply assumptions

The TDP follows a **rigorous** and **iterative** development **process** which is primarily informed by:

- Expected generating capacity and spatial distribution
- Expected electricity demand and spatial distribution
- Stakeholder inputs
 from various sources
- Previous TDPs and other planning activities



Eskom

National Transmission

Company South Africa ™

Generation and Load Assumptions Supporting the Business Case for the TDP 2025 - 2034



The foundational assumptions on electricity generation and load demand are key to ensuring the strength of the TDP planning process. They drive analysis of supply, future demand growth, and technology impacts, providing a solid basis for informed decision-making and sustainable energy strategies. The Grid Code mandates the NTCSA to produce a TDP by October each year, with generation capacity and load assumptions as key inputs. The planning process is dynamic and any changes to input data will be factored into the next TDP as new information is received.

Generation Assumptions

The TDP Generation Assumptions are the generation capacity input to the TDP and uses the Draft IRP 2023⁽¹⁾, currently under review, as its primary source. The IRP Draft 2023 provided 5 pathways for future generation scenarios beyond 2030, 3 are consistent with the reference case and 2 where extreme, therefor the reference pathway 1 was used. Furthermore, key programs like RMIPPPP and REIPPPP BW5, BW6, and BW7, along with Budget Quotation applications (calls for up to 8.9 GW) ⁽²⁾, land lease applications at old power stations (1.9 GW PV), and Eskom's Generation Production Plan⁽³⁾ are factored into the generation assumptions. The total capacity is expected to reach 106.5 GW by the end of the TDP period (2034).⁽⁴⁾

Demand Forecast

The Demand Forecast outlines 6 scenarios for the TDP grid development. Top-down strategic scenarios are supported by bottom-up Customer applications ⁽²⁾ and network analysis. The high scenario aligns with the National Development Plan^{(5),} with 4% GDP growth, industry revival, and highly grid dependable renewable energy expansion, at 47 GW by 2034. The moderate-high scenario projects economic recovery with up to 1.6% GPD growth, reaching 43 GW by 2034. The medium scenario emphasises technological advances and sustainable energy with lower grid connections, predicting 39 GW by 2034 with lower GDP growth at 1% for the decade. The low scenario forecasts minimal growth due to economic decline, staying consistent at 35 GW by 2034, GDP growth on average below 0.5%. The moderate-high scenario is preferred for the TDP planning cycle, aligned with the Draft IRP 2023 ⁽¹⁾ reference forecast, a Macro economic forecast up to 1,6% GDP growth in the TDP period, and up to 3,2% from a global GDP to positively influence South African Growth was used ^{(6) (7)}.


- (1) Integrated Resource Plan (IRP) Draft 2023 | Department of Mineral Resources and Energy.
- (2) Customer Applications Quotation Eskom NTCSA | Grid Planning (2024)
- (3) Eskom Generation Production Plan. (2023)
- (4) Generation Assumption Report 2024.

- (5) National Development Plan 2032 | South African Government (2010).
- (6) National Treasury. (2024). Budget review: Fiscal policy.
- (7) Econometrix (Pty) Ltd (HIS REX Explorer), Eskom service provider.

27

Information flow & data collection






The TDP 2024 assumed a Moderate High demand growth scenario for the infrastructure requirement analysis



| Selected demand scen | | | Selected demand scenario for | ario for TDP 2024 Demand assumptions | | |
|--|--|--|--|---|--|--|
| | | | | | | |
| Parameter | High demand "Fly high and Enable Green Exports" | Moderate High demand "Enable, collaborate with RE grid solutions & markets" | Medium (Energy Efficiency) demand "Sharing the energy supply market" | Low demand "Losing Market Share in the industry, persistent slow economy" | | |
| Global & local economic conditions (GDP%) | Excellent growth >3% in long term | Steady Growth >1,5% in short term and >2% in long term | Moderate to slow growth of <1% in short term, >1% in long term | Deteriorating economic growth <0.5%. | | |
| Load supplied from NTCSA | 46GW in 2034 up to 60GW 2050 | 43GW in 2034 up to 52GW 2050 | 39GW in 2034 Up to 44GW 2050 | 34GW in 2034 up to 36GW in 2050 | | |
| Energy Availability (EAF%) | Very High | High | Moderate | Low | | |
| Network strengthening | Surpass targets | Achieve targets | Below target | Sustain current network only | | |
| Installation of DER including Rooftop, and storage | Low off grid use, mostly using NTCSA for wheeling and grid backup. | Some peak deflection, mostly off-peak use, back up.Wheeling of RE by larger companies. | Great peak deflection and off grid solutions increasing | Mostly grid deflection, great increase in battery storage solutions not connected to the national grid. | | |
| Infrastructure development role out from Government | High | Moderate high | Low | Extremely low | | |
| Hydrogen role out | Hydrogen for local use and export markets | Hydrogen only for local use increasing local beneficiation/manufacturing | No hydrogen local use or production connected to NTCSA | No hydrogen developments | | |
| Energy intense industry for load growth | Hydrogen, Data Centers Local beneficiation & Manufacturing of Steel, Platinum, Battery and PV manufacturing | Data Centers, some hydrogen in the long term. Localized beneficiation of increase in steel, motor vehicles and Battery and PV Manufacturing | Some Data centers, Greater export market for raw materials, no inhouse beneficiation. | Declining data centers connections, all or raw manufacturing exported. | | |
| IRP alignment | Greater than IRP short term, lower in 2050 (IRP 67GW) | On Par with IRP Reference scenario Lower than IRP in 2050 (IRP 64GW) mificant change in spatial distribution of de | Below IRP Low and Reference scenarios, on par with IRP 2040 in long term | Below IRP Low and Reference scenarios, on par with IRP 2030 in long term 30 | | |

Transmission System National Forecast Cycles 2025-2034





Provincial allocation of demand potential for TDP period 2025 - 2034

Top-Down Approach Global Strategic long-term modeling National Scenario scoping 50%Mining Large area/Country/Utility **Strategic** Residentia Chrome Qualitative modeling Hydrogen visions Historic trending Coal Time series HV Networks **HV Networks** Cycle and Trend manufacturing Platinum Small area/ LV Networks LV Networks Smoothing of single customer Data centers profiles Consumer decision Residential 30% 13% Mining Quantitative modelling developments Coincidence factor influence Manufacturing Economic sector load impact Local **EV** uptake Electrification 17% SSEG / RE connection Consumer Quotations Bottom-Up Approach Manufacturing Manganese Electrification / Market Transport Iron ore mining interest Residential Generation 17% **Smelters** 100 Pool %Commercial Hydrogen manufacturing Electricity Other 39% demand Energy sources **Petrochemical plants** Maximum System Demand Hydrogen fuel cell **Robotics** Other demands **Data Centers** (Losses / Manufacturing **Ports** International 27% Auxiliary loads) **Smelters** Transmission **Transport** Transport (EV) Regions Residential Hydrogen **Agriculture** Transmission Manufacturing 30% Areas Hydrogen ansmission Manufacturing Substations stribution Substations \bigcirc \bigotimes

Eskom

National Transmission Company South Africa ™

Generation Assumptions Components

Integrated Resource Plan

(regionally aggregated)

Eskom Generation Plan

data and DFFE EIA

Renewable energy resource



Generation assumptions

NTCSA utilises various insights from internal and external sources...
















 applications
 Annual Renewable Energy Survey
 Government capacity procurement programmes
 Generation Connection Capacity assessment and applications (GCCA)
 Budget Quotations and Land Lease Projects ...which ultimately informs the magnitude and spatial distribution of expected new generation capacity across South Africa, indicating a shift from largely centralised generation to spatially distributed capacity



Total 107 GW by 2034

The TDP 2024 expects generating capacity to increase from 66GW in 2024 to 107GW in 2034, along with a substantial change in technology mix




Generation assumptions

Summary of annual capacity expectations between 2024 and 2034

MW

Cumulative Capacity Per Annum



I: Includes other technologies with minimal changes from previous TDP: Nuclear, Imports, Hydro and Pumped Storage, CSP etc.

Based on the insights from various sources, **capacity** is expected to **increase** from **66GW in 2024** to **107GW in 2034.**


Insights

.

- The **increases** are mainly driven by **Wind**, **Gas**, **Rooftop Solar PV**, and **utility Solar PV** capacity.
- This is **offset by** a **decrease** in **Coal capacity,** as Eskom generation decommissions it's Coal fleet.
- The magnitude of the increases, specifically from sources which are typically more distributed based on geographic resource potential (Wind, Solar PV and Gas), illustrates the significant additional transmission capacity required.

Comparison between the IRP and TDP






• The land lease programme (1.9 GW) addresses replacement projects at different power stations earmarked for decommissioning

Compared to TDP 2022, the TDP 2024 expects an increase in Solar PV, Gas and Coal by 2034 and a decrease in Wind and Battery Storage



Generation assumptions



I: Includes Rooftop Solar PV; 2: Includes other technologies with minimal changes from previous TDP: Nuclear, Imports, Hydro and Pumped Storage, CSP etc.

Overall capacity expected in the TDP 2024 by 2034 remains similar to TDP 2022, with a 0.4GW increase, primarily driven by increased Solar PV (+9GW), Gas (+7GW) and Coal capacity (+3GW) capacity.

Insights

- The increase in Solar PV capacity is driven by Rooftop PV expectations (+9GW by 2034), while the Gas increase (+16GW by 2034) is driven by IRP indications.
- **Coal** is **3GW higher in 2034** compared to TDP 2022, due to **revised shutdown plan** which expects Tutuka to run until 2041.
- **BESS and Wind** reductions are informed by **IRP indications** and **grid constraints**, particularly in the earlier periods.





- Wind capacity decreased by 11.9 GW compared to the last TDP Assumptions
- PV capacity (incl Rooftop) increased by 8.7 GW
- Cumulative Gas increased by 7.3 GW and Battery Storage decreased by 3.8 GW by 2034
- Cumulative Coal and Gas decommissioning will be 17.6 GW by 2034
- Rooftop PV is expected to outstrip utility scale PV by 2034 (14.9 GW v 12.9GW) some say the rooftop is highly underestimated – volatile – lately subdued
- Conventional and imports stabilise at **about** 50% of capacity and RE+ Batteries at 50% by 2034
- The Load forecast selected Moderate High scenario aligns with the IRP load forecast by 2034 and it also tracks the developments in the form of quotations closely



Generation Capacity Analysis & Grid Impacts


Ronald Marais Senior Manager: Strategic Grid Planning



What generation will supply the demand?



(1)



2. IRP and other studies are consistent that solar, wind, energy storage and gas will dominate

IRP 2023 – 36GW renewable by 2030





Figure 8: New Generation Capacity Expected in 2030 by various studies


(1) https://poweroutlook.meridianeconomics.co.za/

Where will renewable generation be located?






(1) https://www.ntcsa.co.za/south-africa-renewable-energy-grid-and-survey/



Coal replacement with new generation requires grid access and transportation to load centers traditionally supplied by the local coal generation





Wind & Solar dominantly located in the South, which is far from the load, hence requires additional grid to enable open access and security of supply to load centers.

Reconfiguring the grid to flow from South to North in two phases




Phase 1 Phase 2 Enhance and optimise existing corridors Establish new corridors


- Reconfigure flow from South to North
- Optimise use of existing assets (Curtailment)

- Create two new corridors from south to north to unlock capacity for new generation and decongest the existing corridor
- The two corridors are the South North Solar corridor in the north and South North costal corridor in the South

Reconfigure Grid to flow from South to North in two phases








Future survey requirements

Existing application and procurement

Understanding grid congestion






How does the generation compare to other plans?



The 38GW is above the IRP and aligned with most other studies except high emission target scenarios.

Wednesday 27 Thursday 28




d 25

Tuesday 26

(1) https://poweroutlook.meridianeconomics.co.za/

Increased urgency for flexibility from energy storage and gas as identified in the various studies to mitigate variability risk

System security and stability considerations



• The TDP highlighted potential system security and stability concerns due to large scale integration of RE that could result in reduced system inertia and strength (short circuit current), voltage and frequency deviations.


National Transmission Company South Africa ™

- Power system dynamic studies confirmed the need for synchronous condensers to maintain system security and stability thereby preventing a grid collapse
- The results of the studies recommended the following: The installation of new synchronous condensers at the following Transmission substations sites:

Koruson, Gamma, Grassridge, Ferrum, Vuyani, Aggeneis and Gromis, as indicated on the map.

2034 Forecasted Generation Capacity





Need to balance the **speed of renewables** with the **speed of flexibility** from energy storage and gas

Flexibility in other countries use large interconnection to adjacent countries to create flexibility. South Africa does not have this flexibility option

Tariff structure are critical to provide incentives for flexibility

Grid-enhancing Technologies



- Dynamic Line Rating (DLR) Hardware and/or software used to appropriately update the calculated thermal limits of existing transmission lines based on real-time and forecasted weather conditions. Often, these schemes establish new limits that safely allow more energy transfer across existing infrastructure.
- Power Flow Controllers (PFC) Hardware and software used to push or pull power, helping to balance overloaded lines and underutilised corridors within the transmission network.
- **Topology Optimisation -** is a software technology that identifies reconfigurations in the grid to route power flow around congested or overloaded transmission elements.
- Advanced high temperature low sag (HTLS) conductor can withstand operating temperatures of up to 210 °C, thus carrying higher power compared to conventional conductors.

Grid-Enhancing Technologies:

A Case Study on Ratepayer Impact

February 2022

These technologies are applicable to short distance meshed networks. Although there are some application near Gauteng, the main capacity challenge in South Africa's grid is long distance large power transfer.

(1) https://www.energy.gov/sites/default/files/2022-04/Grid%20Enhancing%20Technologies%20-%20A%20Case%20Study%20on%20Ratepayer%20Impact%20-%20February%202022%20CLEAN%20as%20of%20032322.pdf

What emerging technologies have potential for the future grid services?



GET INVOLVED

Q



Why this is the most critical topic to address to achieve 100% clean energy goals

Ben Kroposki, PhD, PE, FIEEE UNIFI Organizational Director Monday, August 30, 2021

First Grid-Forming 300 MVAr STATCOM in Germany

June 4, 2024 by Moritz Mittelstaedt, Amprion GmbH



Who We Are $\, \lor \,$ What We Do $\, \lor \,$ Where We Work $\, \lor \,$ Our Impact $\,$ News & Events $\,$ Resources $\, \lor \,$

G-PST/ESIG Webinar Series: Is "Grid Forming" Enough: What Do Electricity Grids Need From IBR?

G-PST/ESIG Webinar Series: Is "Grid Forming" Enough: What Do Electricity Grids Need From IBR?

| Q Search |
|----------|
|----------|



TDP 2024: Provincial Development Plans

Compiled by: Grid Planning Chief Engineers Presented by: **Ahmed Hansa** / **Caroleen Naidoo**





TDP 2024: Southern Supply Area


(Free State, Northern Cape, Eastern Cape and Western Cape)

Ahmed Hansa Chief Engineer: Grid Planning



Southern supply areas – existing network overview






• The Southern supply areas are:


- Northern Cape
- Eastern Cape
- Western Cape
- Hydra Central
- Free State
- The **peak load** in 2024 was **7 GW**, which is 20% of the national peak load of **34 GW**.
- The installed generation is **I4 GW**.

| Туре | Base Load | Peaking | Renewable |
|-----------------|-----------|-----------|-----------|
| Nuclear | 1860 | | |
| Hydro | | 600 | |
| OCGT Gas | | 2744 | |
| Pumped Storage | | 400 | |
| Battery Storage | | | 151 |
| CSP | | | 600 |
| PV | | | 2783 |
| Rooftop PV | | | 1652 |
| Small Hydro | | | 10 |
| Wind | | | 3548 |
| Sub Total | 1860 | 3744 | 8744 |
| Grand Total | | 14 348 M\ | ▶ 54 |














- 32 existing substations were identified where 53 additional transformers will be installed.
- 42 of these transformers will enable connection of up to 20 000 MW of RE generation, I I will provide redundancy for both load and generation.

2025 – 2029


Aggeneis transformer (1) Aries transformer (1) Boundary transformers (2) Dedisa transformers (2) Delphi transformer (1) Droerivier transformers (3) Gamma transformers (2) Garona transformers (2) Grassridge transformer (1) Groeipunt transformer (1) Gromis transformer (1) Helios transformer (1) Hydra transformers (2) Juno transformer (1) Kappa transformer (1) Komsberg transformers (2) Kronos transformers (2) Mookodi transformer (1) Nama transformer (1) Paulputs transformer (2)

Pembroke transformers (2) Philippi transformer (1) Pinotage transformer (1) Stikland transformer (1) Theseus transformer (1) Upington transformers (3)

2030 – 2034


Aries transformer (1) Aurora transformer (1) Aggeneis transformer (1) Everest transformer (1) Grassridge transformer (1) Harvard transformers (2) Kappa transformers (2) Kronos transformer (1) Leander transformer (1) Merapi transformer (1) Nieuwehoop transformers (2)





Southern supply areas – additional 400 kV lines





• Whilst most of the new substations are connected to existing lines, new lines are required to integrate and evacuate excess power to the main corridors.

• 3 655 km of 400 kV lines will need to be constructed.


2030 - 2034

2025 – 2029

| Juno – Gromis I | 280 km | Aggeneis – Aries 2 | 200 km |
|----------------------------|--------|-------------------------|--------|
| Aries – Upington I | I44 km | Beta – Harvard I | 70 km |
| Ferrum – Upington I | 260 km | Coega – Dedisa I | 8 km |
| Aggeneis – Paulputs I | 93 km | Coega – Dedisa 2 | 8 km |
| Hydra – Kronos 2 | 190 km | Coega – Grassridge I | 15 km |
| Kronos – Aries 2 | 162 km | Coega – Poseidon I | II0 km |
| Aggeneis – Groeipunt I & 2 | 126 km | Dedisa – Hlaziya I | 123 km |
| Aurora – Bokkom I & 2 | 50 km | Droerivier – Gourikwa I | 235 km |
| Aurora – Juno 2 | 160 km | Gamma – Droerivier I | 200 km |
| Beta – Boundary I | 95 km | Grassridge – Hlaziya I | II6 km |
| Boundary – Ferrum I | 265 km | Harvard – Merapi I | II0 km |
| Ferrum – Mookodi 2 | 260 km | Paulputs loop-ins | 96 km |
| Groeipunt – Nama I | 41 km | | |
| Gromis – Nama I | 76 km | | |
| Pembroke – Poseidon I | 162 km | | |
| Pembroke – Neptune I | 50 km | | |


Additional corridors





Synchronous condensers





- Decommissioning of some of the **baseload coal plants** in **Mpumalanga** will likely be **replaced with inverter based RE**, mainly wind and solar in the **Greater Cape regions.**
- This will result in a need for **7 sites for synchronous condensers** to provide inertia, voltage support and short circuit power.
- These will be installed at:
 - Gromis
 - Aggeneis
 - Ferrum
 - Gamma
 - Koruson
 - Grassridge
 - Vuyani



TDP 2024: Northern Supply Area


(Limpopo, North West, Gauteng, Mpumalanga and Kwa-Zulu Natal)

Caroleen Naidoo Chief Engineer: Grid Planning




Northern supply areas – existing network overview










• The **peak load** is forecasted to grow from **28 GW** to **35 GW**.

• With the transition towards cleaner and greener energy, and the decommissioning of coal generation, the generation capacity in the north is expected to remain around 55 GW.

Northern supply areas – dispatched generation scenario and forecasted midday load






• The midday load is forecasted to grow from 26 GW to 31 GW.

 Considering capacity factors and economic generation dispatch, the Northern supply areas become net **importers** of up to **15 GW** of power over the next ten years.

• Therefore, major corridors are required to import power from the south of the country.


North West – transformers, new substations and lines






Limpopo – transformers, new substations and lines






Mpumalanga – transformers, new substations and lines






Gauteng – transformers, new substations and lines






KwaZulu-Natal - transformers, new substations and lines





Additional corridors








Additional Projects since TDP 2022 Transmission Development Plan



Additional projects since TDP 2022





- TDP 2024 has been revised to factor in new capacity requirements.
- The TDP 2024 requires similar transmission line build and increased transformer capacity compared to TDP 2022.
- In addition, the TDP 2024 highlights the need for:
- 7 sites for synchronous condensers
- 16 substations of which 9 are current projects
- 40 transformers



Summary of Grid Assets Refurbishment Plans

Atha Scott Senior Manager: Asset Investment Planning




Introduction




- Refurbishment is critical to network sustainability and deals with the systematic renewal of the network assets, based on plant performance and equipment condition.
- This is further supported by the assurances provided by ensuring adequate capital spares, availability of emergency preparedness plans, system operator guidelines, production equipment and asset maintenance.
- Asset Management is focused on the existing network assets (or the installed base of assets), and to sustain that existing network infrastructure at desired performance levels.
- This is achieved by removing risks from the network through the *replacement of poor condition / unreliable assets*, with consideration of network constraints. Asset Management principles form the basis of prioritising which assets need to be replaced, whilst *maintaining a balance between performance, cost, and risk*. This is supported by a standardised refurbishment prioritisation methodology.
- The development of a robust Refurbishment Plan is therefore crucial and is formulated by identifying refurbishment requirements in terms of capital investments that would ensure that the network conforms to the required reliability and statutory standards.
- The purpose of the presentation is to give an overview of the status of the existing network assets and the planned investments to address the network risks by means of asset replacements.

Substation Asset Condition Assessment: (National View of the Main Asset Classes)






ASSET CONDITION PER CATEGORY




- Periodic asset assessments of all substation asset classes across the transmission network are conducted.
- The graph represents the latest overall condition of the key asset classes of the installed base.

Overhead Powerlines: Asset Condition Assessment (National View of the Main Asset Classes)








- The Overhead Powerlines were broken up into its key components that make up a powerline and evaluated to generate the overall asset condition based on a weighted condition assessment.
- This condition assessment was done per line component to derive an overall assessment across all the powerlines in the transmission network.


Assets replaced and planned for replacement





| | CATEGORY | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | Grand Total |
|--|--------------------|------|------|------|------|------|------|------|------|------|------|----------------|
| | CAPACITOR | - | - | - | - | - | - | - | - | - | 2 | 2 |
| | CIRCUIT BREAKER | 55 | 55 | 41 | 29 | 41 | 48 | 37 | 40 | 59 | 39 | |
| | CURRENT TRANSFORME | 96 | 194 | 190 | 140 | 228 | 225 | 236 | 202 | 219 | 182 | 1 912 |
| | DC & STANDBY | 70 | 29 | 62 | 22 | 19 | 41 | 5 | 5 | 28 | 89 | 370 |
| | ISOLATORS | 22 | 35 | 40 | 24 | 31 | 34 | 43 | 57 | 101 | 85 | 472 |
| | PROTECTION | 20 | 37 | 36 | 31 | 51 | 26 | 37 | 40 | 43 | 28 | 349 |
| | REACTOR | 6 | 19 | 6 | 3 | 1 | 2 | 1 | 2 | 1 | - | 41 |
| | SURGE ARRESTER | 128 | 192 | 276 | 112 | 155 | 187 | 200 | 131 | 165 | 126 | 1 672 |
| | TRANSFORMER | 9 | 12 | 13 | 9 | 11 | 8 | 4 | 4 | 4 | 15 | 89 |
| | VOLTAGE TRANSFORME | 47 | 54 | 45 | 39 | 77 | 81 | 138 | 59 | 103 | 89 | 732 |
| | Grand Total | 453 | 627 | 709 | 409 | 614 | 652 | 701 | 540 | 723 | 655 | 6 083 |





| CATEGORY | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | Grand Total |
|---------------------|------|-------|-------|-------|-------|-------|-------|-------|-------|-------|----------------|
| CAPACITOR | 1 | 5 | 4 | 7 | 12 | 5 | 5 | 9 | 1 | 6 | 55 |
| CIRCUIT BREAKER | 48 | 87 | 131 | 90 | 115 | 69 | 105 | 117 | 83 | 85 | 930 |
| CURRENT TRANSFORMER | 192 | 425 | 577 | 438 | 460 | 406 | 438 | 394 | 293 | 239 | 3 862 |
| DC & STANDBY | 80 | 43 | 28 | 28 | 22 | 14 | 6 | 28 | 4 | 28 | 281 |
| ISOLATORS | 139 | 213 | 416 | 331 | 332 | 324 | 431 | 501 | 343 | 343 | 3 373 |
| PROTECTION | 35 | 141 | 214 | 256 | 249 | 275 | 315 | 257 | 201 | 51 | 1 994 |
| REACTOR | - | - | - | - | - | 4 | 9 | 2 | 1 | - | 16 |
| SURGE ARRESTER | 68 | 116 | 280 | 182 | 231 | 230 | 265 | 431 | 245 | 307 | 2 355 |
| TRANSFORMER | 1 | 1 | 8 | 7 | 13 | 13 | 15 | 27 | 31 | 8 | 124 |
| VOLTAGE TRANSFORMER | 23 | 100 | 206 | 193 | 115 | 182 | 216 | 221 | 96 | 166 | 1 518 |
| Grand Total | 587 | 1 131 | 1 864 | 1 532 | 1 549 | 1 522 | 1 805 | 1 987 | 1 298 | 1 233 | 14 508 |

A. Operational Risks:

- 1. HV Plant Assets:
- High-Risk Transformers and Reactors are addressed in a phased approach based on network risk.
- Insulation flashover mitigation by re-insulation or surface coating at highly polluted areas.
- Problematic Instrument Transformers and Surge Arrestors that have degraded and become unreliable. These are addressed as targeted replacements.

Comdany South Africa ™

- Circuit Breakers: Application requiring technological advancements and improved functionality.
- Replacement of the poor condition **Breakers** due to degradation.
- Performance improvement of Shunt Capacitor Banks.

2. Protection Schemes:

- Protection schemes are being addressed as a priority focus area and will require an extended replacement programme.
- The strategy is to replace the protection schemes that are showing performance deterioration due to failures and are being prioritised for replacement by specific protection replacement projects.
- The strategy going forward is to replace up to phase 5, as it is deemed prudent as these are past end of design life.
- However, certain schemes need replacement due to obsolescence and the unavailability of spares.
- As an interim measure, spares are being harvested to address the schemes that are problematic.

Refurbishment Plan Focus Areas (cont.)

3. Powerline Assets:

• Foundations: Several line foundation designs (built prior to 2004) allowed for bare steel to be in direct contact with the soil, which results in degradation based on soil type and weather.

Comdany South Africa ™

- Insulation and Hardware: Spacer dampers exhibit a lower level of reliability due to the accelerated wear and tear on the conductor.
- Line Insulation is the least reliable of the line components, being under-insulated brought about by changes in design standards, thus forming the bulk of the line asset replacements.

4. Fibre:

 Fibre Wrap (e.g. Adlash) installed on some line earth-wires have exceeded their expected lifespan and are now impacting on the line performance. These need to be replaced with **Optical Ground Wire** (OPGW), which generally is very costly and outage dependent.

B. Statutory Risks:


- 1. <u>Compliance Requirements:</u>
- Assets requiring replacement due to fault-level exceedances becoming under-rated for its location due to network expansion
- Environmental legislation in terms of Asbestos and PCB phase-out (completed)
- Adequacy of Oil Containment

2. Infrastructure Security:

- Addressing statutory fencing requirements for safety, operating and proximity to High Voltage
- Security upgrades to address breaches and theft


Major Substation Refurbishments: FY2025 – FY2034






Major Powerline Refurbishments: FY2025 – FY2034









Conclusion



- The refurbishment plan focusses on *problematic and unreliable assets* that have impacted the NTCSA over the past years due to deterioration, mal-operation, latent defects, performance issues, obsolescence, and statutory fault-level compliance.
- The objective of the refurbishment plan is to *ensure long-term sustainability* of the network and optimal usage of the capital allocation.
- The NTCSA has an adequate planning process to determine asset replacement requirements, which is aligned to Asset Management principles.
- The current portfolio of projects in the Transmission Network Refurbishment Plan (TNRP) considers the risks to the network and embodies the requirements and stipulations of the Grid Code.
- The 10-year refurbishment plan is based on *actual asset condition assessments, asset criticality, network risks that undergoes a robust prioritisation process.*
- The plan is further flexible enough to accommodate emerging operational risks and current requirements in addition to the planned asset replacement program.
- In conclusion, the major refurbishment projects as displayed, are an indication that the refurbishment plan addresses requirements across the country.



TDP 2024 Summary

Leslie Naidoo Senior Manager: Grid Planning



The TDP challenges




Current situation

- The draft IRP 2023 proposes ~ 30 GW of new generation capacity by 2030. By 2034 this increases to ~ 56 GW based on the draft IRP 2023 base case, and applications processed via the DMRE and non-DMRE (private sector) procurement programmes.
- Large scale penetration of RE coupled with reduction in base load generation will impact the system stability from an inertia, voltage and system strength perspective and will require compensation devices.
- Current network reliability constraints (N-1), as well as meeting the anticipated demand growth also requires significant new grid infrastructure.
- This necessitates an acceleration of investments in transmission infrastructure by development of new corridors and substations, and strengthening at existing substations over the period 2025 – 2034 to address both the new generation capacity, as well as the network strengthening requirements across the country to ensure security of supply.


Problem statement

- The grid strengthening required to accommodate this aggressive renewable integration, as well as ensuring the sustainability of the network requires **significant investments**.
- Timelines to implement transmission infrastructure takes ~ 8 10 years to build due to servitude challenges
- The resource capacity in the country across the EPCM value chain is limited.
- The TDP 2024 is based on the draft IRP 2023, while the new IRP is being finalised. However, the TDP analysis indicates that, at least in the first 5-year period, not much changes are anticipated. Hence, there is more confidence in the infrastructure and capital requirements for this period. Beyond the 5-year horizon, the "uncertainty" increases and as more information becomes available, it would be factored in the next version of the TDP. The focus of the TDP 2024 is therefore on the first 5-year horizon, while the next 5-years is more for information of what could be expected based on the assumptions considered.



Transmission demand and generation summary







- A moderate-high forecast was used for planning purposes that indicates a national peak demand of ~ 43 GW by 2034
- Expected generation capacity to reach ~ 107 GW by 2024, an increase of ~ 56 GW of new capacity

Transmission network challenges







Lower load in the South remains




Generation increase in the South






















TDP 2024 UPDATE The transmission infrastructure expansion projects will stretch across all provinces in South Africa








Spatial overview of transmission capacity expansion projects

Spatial overview of Synchronous Condenser requirements




NTCSA is also driving actions to increase grid connection capacity and streamline grid connection process in the short term






| Increased connection | ction capacity | | | | | |
|-------------------------|--|--|--|--|--|--|
| Congestion curtailment: | 3.5 GW of additional connection capacity in the Western and Eastern Cape | | | | | |
| Priority Projects | I3 GW via priortised transformer projects by 2030 | | | | | |
| | 24 GW via expedited projects by 2033 | | | | | |
| | | | | | | |
| Connection stre | amlining | | | | | |
| Connection stre | amlining 2025 RE Grid Survey to better understand IPP demand for grid development | | | | | |

Accelerating grid capacity for RE integration: Priority transformer and line projects to integrate 37GW of new generation capacity






2026 and ending in 2033.


Eskom

National Transmission Company South Africa ™

TDP 2024 | Summary of infrastructure requirements







| Transformers | | | | | | | | | | |
|--------------|-----------------|-------------|-------------|-------------|--|--|--|--|--|--|
| | Transmission | Total New | Total New | Total New | | | | | | |
| | Assets | Assets: | Assets: | Assets: | | | | | | |
| | Nationally | 2025 - 2029 | 2030 - 2034 | 2025 - 2034 | | | | | | |
| | Transformers | | | | | | | | | |
| | Number of Units | 87 | 123 | 210 | | | | | | |
| | Capacity (MVA) | 41325 | 91325 | 132650 | | | | | | |
| Capacitors | | | | | | | | | | |
| | Transmission | Total New | Total New | Total New | | | | | | |
| | Assets | Assets: | Assets: | Assets: | | | | | | |
| | Nationally | 2025 - 2029 | 2030 - 2034 | 2025 - 2034 | | | | | | |
| | Capacitors | | | | | | | | | |
| | Number of Units | 15 | 25 | 40 | | | | | | |
| | | | | | | | | | | |

1032

1660

2692

Capacity (MVar)




TDP 2024: Capex Analysis and Challenges



TDP 2024 ~ 5-year capital plan FY25 – FY29



Transmission TDP 2024 PLCM Capex Summary (R bn):



Challenges / Actions:

 Based on the network requirements,
 ~ 5 044 km of power lines and 87 transformers are expected between 2025 – 2029

Key Challenges:


- Securing servitudes timeously
- Supplier and construction capability


Actions taken:

- NECOM Work Stream 4 and TDP implementation Steerco established to oversee and expedite the TDP roll-out programme
- Prioritisation of the project portfolio
- Secured adequate capex for the first 5years of the plan

NTCSA's 5-year capex plan: FY25 – FY29







Note:

- The TDP is an unconstrained plan that addresses the country's aspirations (IRP)
- In the short-term, the focus is on expediting the TDP delivery and maximizing on available capex





NTCSA is supportive of innovative funding solutions such as ITPs...



...but enablers need to be put in place to ensure successful implementation

The NTCSA Board has ratified the Build and Transfer model

Board supports proposed ITP pilot project

Management exploring other models such as Build, Operate and Transfer

Board mandated CEO to secure resources to support PSP initiatives

Implementation of ERAA to enable S34B Ministerial determinations for new transmission infrastructure procurement

NTCSA is working with Ministry to develop regulations needed for ITP


Innovative solutions required to avoid encumbering NTCSA balance sheet

Cost-reflective tariff structures, policies and adequate capitalisation to ensure the NTCSA's financial sustainability


Major risks to deliver the TDP for which the NTCSA is already implementing solutions



Challenges and solutions



Summarised framework for planning and rollout of TDP projects



• The outcome of the TDP is a list of projects with a high-level scope, cost, and time for the new infrastructure.

Eskom

National Transmission Company South Africa ™

- Each project then goes through an individual detail technical / economic analysis and culminates with a business case.
- The execution of individual projects follows the project life cycle model (PLCM) and the NTCSA's governance approval process prior to development and implementation.
- Current implementation practices involve internal engineering, procurement and construction management (EPCM) and recently introduced owner's engineer (OE) and engineering, procurement and construction (EPC) panels to supplement internal capacity.
- Working closely with the DoEE to develop a framework to introduce private sector participation (PSPs) / independent transmission projects (ITPs) as an alternate model to develop and fund infrastructure roll-out for the NTCSA.



Progress on TDP Implementation Plan

Makgwanya Maringa Senior Manager: Project Delivery



Introduction




- NTCSA has a mature pipeline of project at various stages of development to deliver the TDP 2024 targets.
- NTCSA has identified priority projects to implement in the medium to long-term strategies to unlock 37 GW.
- NTCSA is already implementing strategies to overcome challenges across the value chain.
- The TDP Implementation Steering Committee and Energy NatJoints Workstream 4 were established to ensure the successful delivery of the TDP.



TDP 2024 | Expansion Projects across the Project Life Cycle Model (PLCM)


Expansion Projects across PLCM as of 30 September 2024

Overhead power lines (circuit kilometers)



Expansion Projects across PLCM as of 30 September 2024

Transformer capacity (MVA)



Pre-Concept

- Planning report
- User Requirements Specification(URS)

National Transmission

Company South Africa [™]

• Prepare for concept design approval

Concept

- Preferred technical solution & concept design
- Site and route selection
- Environmental screening studies


Definition


- Detailed design
- Securing land & regulatory approval

Execution

- Equipment & contractor procurement
- Construction of infrastructure

Progress in Expansion Program from 1 November 2022 to 30 September 2024 (# of projects)






National Transmission Company South Africa ™

> 10 107

7

Priority programme | 47 priority projects have been identified to accelerate 37 GW of new connection capacity by 2033




Eskom


National Transmission

Company South Africa [™]

Priority programme | Projects have shifted to the execution phase since 2023

Distribution of priority programme projects across PLCM as at 30 September 2024 Capacity enabled (MW) **Priority Program in Procurement and Construction as at 30 September 2024** Capacity enabled (MW)





Procurement MW Enabled

Construction MW Enabled

National Transmission

Company South Africa [™]

TDP2024 | 5-year delivery plan (FY25 to FY29)


2,500 45 2,000 1,500 1,868 1.238 1,000 500 232 423.1 418 286 318 209 0 **FY25 FY26 FY27 FY29 FY28**

Overhead power line delivery pipeline for FY 2025-2029

(km)

- FY25 plan as of September 2024 was 89km, 75.8km has been achieved, which is 84% of the YTD plan (Sep 2024)
- For FY26 363km (86%) is already in construction and 60km (14%) is in the final stages of procurement
- 5 043km to be achieved by FY29, these includes projects both in development and execution phases.

Transformer delivery pipeline for FY 2025-2029 (\mbox{MVA})



National Transmission Company South Africa ™

- FY25 plan of 2380MVA (6 transformers) is planned to be commissioned by March 2025.
- For FY26, 2250MVA (5 transformers) civil work has commenced and 1500MVA (3 transformers) the contracts for civil work are in the final stage of procurement. All the transformers have been ordered.
- 41 165 MVA to be achieved by FY29, these includes projects both in development and execution phases.

Delivery initiatives | Development and execution challenges





Servitude acquisition

Environmental approval

Constrained resource capacity




Execution Phase Challenges

- Safety performance
- Tender re-issue and non-responsive tenders
- Primarily delays in the manufacturing and delivery of equipment (e.g., transformer and steel supply)
- Community unrests
- Contractor performance

Delivery initiatives | Initiatives in place





1145 schedules captured in one tool Analytics tool showing milestones and physicals is now in use



Line contractor incubation has started. **2 Suppliers** completed the program in **Oct '24**. Intake will be annual

Transformer & Steel Supply


the program (one-stop shop)

Accredited 22 factories for Class 3B Transformers 101 Transformer contracts awarded May '24. 1st batch (22/26 Transformers) awarded Aug'24

6 Steel suppliers invited to prepare prototype towers; 2 suppliers delivered prototypes for final inspection₁iη₂ Oct' 24

Delivery initiatives | Initiatives in place





2027 2028

🗩 Limits 📃 Total



| | | Internal EPCm | EPC | EPCm | ITP |
|----|------------------------------|---|--|--|--|
| 24 | Who designs & executes | NTCSA manages entire project incl. design & execution | 3 rd party designs and executes based on scope | NTCSA owners' engineers manage 3 rd party to design & execute | 3 rd party designs and executes based on scope |
| | Who owns | • | NTCSA | | 3rd party owns specific project assets for fixed period, after which it returns to NTCSA |
| 0 | Enablers | Ensure adequate resource planning, programme management & project planning. | EPC Panel established | OE Panel established | Pilot project supported Awaiting Regulations and Determination, enable S34B Cost-reflective tariff structures, policies & adequate capitalisation to ensure NTCSA's financial sustainability |

Conclusion



- Acceleration of projects into execution
- Significant progress has been made on key delivery initiatives
- NTCSA continues to implement strategies to deliver infrastructure that will unlock the grid
- Strategic and operational forums have been established to address challenges during the infrastructure delivery program
- Current outlook indicate shift in readiness and capability to deliver set targets
- The TDP delivery challenges such as construction capacity, equipment supply, and statutory approvals are being addressed to ensure successful delivery of the programme



What does TDP delivery success look like?



- Safe execution Zero Harm
- Ethical behavior Integrity
- Deliver excellently engineered, constructed, best performing assets
- Positive impact on communities







Thank you





Conclusion



Q&A Session



Thank you for attending!